



Contra Costa CCD Electrification Study

Steinberg Hart

June 3, 2024

PREPARED BY

Steve Gross PE, BEMP

PRINCIPAL

Wesley Lau PE, LEED AP

PRINCIPAL

Jacob Jay

BUILDING PERFORMANCE ANALYST

Table of Contents



Table of Contents

| | | | | | |
|----------|---|-----------|----------|--|------------|
| 0 | Introduction | 4 | 4 | District Office | 132 |
| 1 | Los Medanos College/Brentwood Education Center | 6 | | Carbon and Energy Benchmarking | 133 |
| | Carbon and Energy Benchmarking | 7 | | Electric Infrastructure Assessment | 136 |
| | Electric Infrastructure Assessment | 18 | | Renewable Energy Deployment | 140 |
| | Renewable Energy Deployment | 25 | | District Energy Projects | 143 |
| | District Energy Projects | 29 | | Energy Timeline | 150 |
| | Energy Timeline | 43 | 5 | District Wide Summary | 154 |
| 2 | Contra Costa College | 50 | | Electric Infrastructure Assessment | 155 |
| | Carbon and Energy Benchmarking | 51 | | Renewable Energy Deployment | 160 |
| | Electric Infrastructure Assessment | 60 | | District Energy Projects | 162 |
| | Renewable Energy Deployment | 66 | | Energy Timeline | 165 |
| | District Energy Projects | 69 | 6 | District Future Energy and Carbon Scenarios | 170 |
| | Energy Timeline | 80 | | Emissions Cost Comparison | 171 |
| 3 | Diablo Valley College/ San Ramon Center | 84 | | Future Scenario A: Main Scenario | 174 |
| | Carbon and Energy Benchmarking | 85 | | Future Scenario B: No Future PV, More Offsets | 178 |
| | Electric Infrastructure Assessment | 97 | | Future Scenario C: Clean Electricity Purchase, Minimal Offsets | 182 |
| | Renewable Energy Deployment | 103 | | Future Scenario D: Delayed Electrification, PV Matched to kWh Consumption, Offsets for Gas | 186 |
| | District Energy Projects | 107 | A | Resources and Information Around Carbon Offsets and Capture | 193 |
| | Energy Timeline | 125 | | | |

0.

Introduction

Introduction

The purpose of this study is to support the Facilities Master Plan for the Contra Costa Community College with a district-wide electrification plan. The plan provides an analysis of how electrifying the district's natural gas heating systems and deploying renewable energy systems will reduce the district's energy consumption and carbon footprint, as well as alleviate the burden of having to maintain, and rely on, old gas lines and infrastructure.


The primary goal of the electrification plan is to assist the district in meeting its sustainability goals, as outlined in the "2022 4CD District Wide Energy & Sustainability Goals" document.

The electrification plan consists of the following components:

- Building Benchmarking Report
- Electrical Systems Assessment
- Campus Photovoltaic Deployment Assessment.
- Building Electrification Strategy
- District Energy and Carbon Timeline

The plan is structured in a way that first benchmarks each campus to understand the current energy and carbon intensity of the various buildings. Next, the utility services at each campus are assessed to determine the available spare capacity for increased electrical load and renewable energy generation. The third step of the study is to identify the potential to deploy additional photovoltaic systems on each campus, corresponding to the available capacity and future electrical load.

The fourth component of the study proposes strategies for electrifying and improving the efficiency of existing buildings and estimates the impact to campus energy and carbon intensity. Finally, a district wide summary of the interventions is presented, accounting for the changes in electricity and gas consumption, as well as renewable energy production through 2040.



1.

Los Medanos
College/Brentwood
Education Center

Carbon and Energy Benchmarking



Building Benchmarking Study - Introduction


As part of the District Sustainability and Electrification plan, the portfolio of campus buildings has been subject to a benchmarking study to attempt to determine the highest priority target buildings for electrification and chart a path for the district towards meeting its sustainability goals. The data used for this benchmarking study consists of engineering and architectural drawings provided by the community college district, campus wide electricity and gas usage data, and results from a building equipment and facilities audit performed by Bureau Veritas. Building EUIs were also adjusted based on known operational configurations for particular campuses and buildings, as well as the mechanical and air systems.

Electricity and gas usage was estimated for each individual building on the campus based on available benchmarking data by building type for the bay area climate zones, the state of California as a whole, and available campus wide billing data. These estimates were then adjusted based on known building specific characteristics. Large multi-purpose campus buildings were divided into the various use-types they are composed of in order to provide an accurate EUI estimate for the building, as well as a use-type specific EUI for that campus.

The estimates were then revised based on a dialogue with the district on the values, particular building meter data, multi-building line meter data, and site electricity data that was made available.


The energy and carbon impact of the pools were estimated based on available boiler data for the Contra Costa College pool and then a gas usage per square foot per year was applied to the Diablo Valley College pool in order to estimate the portion of the gas usage that is not part of a building EUI.

Building type energy data from the bay area, California, and the United States came from the [Lawrence Berkley National Laboratory Building Performance Database](#) and was adjusted or compiled into campus use types based on engineering judgement.




Sample BPD Query

The Energy Star [Commercial Buildings Energy Consumption Survey](#) and data from the [Higher Education Benchmarking Initiative](#) were also used to estimate end-use breakdowns and as a comparison point for realistic data for particular types of campuses.




Sample CBECs Data

LMC 2022 Weather Normalized Campus EUI (kBtu/sf)



■ Building Elec EUI ■ Building Gas EUI ■ Site Electricity EUI

LMC 2022 Weather Normalized Campus Emissions Breakdown




■ Total Elec Emissions ■ Total Building Gas Emissions

LMC

Campus-Level Benchmarking

The campus EUI graph sums the total gas and electricity associated with the campus and divides them by the square footage of campus buildings included in the EUI study. The breakdown is representative of the split between gas and electricity use on the campus. The campus emissions chart shows the portion of the campuses total emissions that are associated with each fuel type. This data is all based on weather normalized data for the gas and electricity use and does not exactly match the real quantities but is better for a forward-looking analysis of the campus energy. LMC electricity use is associated with Constellation energy which as a grid emissions rate of 701 lbs CO₂e per MWh of electricity. The area for EUI calculations in 2022 was 411,600 ft²

LMC Campus Area Breakdown (Percent)




LMC

Campus Program Breakdown

The campus area breakdown shows the portion of the campus square footage associated with each of the program type categories in our study. Buildings with multiple use types have had their square footage distributed proportionally.

Program EUI - LMC (kBtu/sf)




LMC

EUI per Program Type

The program EUIs are based on the weighted average of individual EUIs of buildings in each program classification, which may vary. These programs were assigned for energy analysis purposes and may not match other campus program breakdowns.

LMC Building EUI Breakdown (kbtu/sf-yr)*




LMC

Energy Breakdown
by Building

*Some buildings with negligible energy use are excluded from this graph

Total Carbon Emissions (Kg C02e)




LMC


Carbon Emissions by Building

LMC Benchmark Data Summary Table


| Building | Age | Area | EUI | Gas EUI | Electric EUI | Total kBTU | Gas kBTU | Elec kBTU | Gas Carbon Emissions (metric tons CO2) | Electricity Carbon Emissions (metric tons CO2) | Total Carbon Emissions (metric tons CO2) |
|-------------------------------|------|---------|-------|---------|--------------|------------|-----------|-----------|--|--|--|
| COLLEGE COMPLEX | 1977 | 148,126 | 101.3 | 48.6 | 52.7 | 15,002,426 | 7,201,930 | 7,800,496 | 382 | 728 | 1,111 |
| SCIENCE | 2008 | 51,469 | 55.4 | 25.2 | 30.2 | 2,853,441 | 1,297,019 | 1,556,423 | 69 | 145 | 214 |
| CORE BUILDING | 1974 | 27,726 | 86.2 | 38.1 | 48.2 | 2,391,090 | 1,055,806 | 1,335,284 | 56 | 125 | 181 |
| STUDENT UNION | 2020 | 29,017 | 72.0 | 34.4 | 37.6 | 2,088,744 | 997,883 | 1,090,860 | 53 | 102 | 155 |
| LIBRARY | 2006 | 34,677 | 44.0 | 25.8 | 18.2 | 1,525,355 | 893,366 | 631,988 | 47 | 59 | 106 |
| MATH | 2008 | 23,009 | 61.6 | 32.2 | 29.4 | 1,417,354 | 740,890 | 676,465 | 39 | 63 | 102 |
| KINESIOLOGY/ATHLETICS COMPLEX | 2020 | 30,153 | 42.4 | 25.8 | 16.6 | 1,277,643 | 777,465 | 500,178 | 41 | 47 | 88 |
| MUSIC ADDITION | 1994 | 13,345 | 83.2 | 35.3 | 47.9 | 1,109,770 | 470,812 | 638,959 | 25 | 60 | 85 |
| CHILD STUDY CENTER | 1974 | 13,197 | 85.0 | 40.0 | 45.1 | 1,122,197 | 527,497 | 594,700 | 28 | 56 | 84 |
| GYM | 1974 | 19,940 | 48.2 | 33.4 | 14.8 | 961,587 | 665,916 | 295,670 | 35 | 28 | 63 |
| CAMPUS SAFETY CENTER | 2019 | 3,430 | 63.0 | 0.0 | 63.0 | 216,090 | 0 | 216,090 | 0 | 20 | 20 |
| EE TEC PORTABLE CLASSROOM | 2008 | 2,179 | 49.0 | 0.0 | 49.0 | 106,771 | 0 | 106,771 | 0 | 10 | 10 |
| MAINTENANCE & UTILITY | 1973 | 5,848 | 16.5 | 0.0 | 16.5 | 96,492 | 0 | 96,492 | 0 | 9 | 9 |
| STORAGE - AUTO SHOP | 2000 | 2,300 | 15.0 | 0.0 | 15.0 | 34,500 | 0 | 34,500 | 0 | 3 | 3 |
| SCIENCE - MECH/CHILLER | 2008 | 851 | 15.0 | 0.0 | 15.0 | 12,765 | 0 | 12,765 | 0 | 1 | 1 |
| CONCESSION | 1963 | 900 | 11.0 | 0.0 | 11.0 | 9,900 | 0 | 9,900 | 0 | 1 | 1 |
| STORAGE - M&O | 1973 | 480 | 15.0 | 0.0 | 15.0 | 7,200 | 0 | 7,200 | 0 | 1 | 1 |
| SC - ETEC | 2008 | 480 | 15.0 | 0.0 | 15.0 | 7,200 | 0 | 7,200 | 0 | 1 | 1 |
| STORAGE - GROUNDS | 1973 | 166 | 15.0 | 0.0 | 15.0 | 2,490 | 0 | 2,490 | 0 | 0 | 0 |
| STORAGE - NATURE PRESERVE | 1999 | 164 | 15.0 | 0.0 | 15.0 | 2,460 | 0 | 2,460 | 0 | 0 | 0 |



BEC 2022 Weather Normalized Campus EUI (kBtu/sf)



BEC 2022 Weather Normalized Campus Emissions Breakdown



Brentwood Education Center

Campus-Level Benchmarking

The Brentwood Education Center has a somewhat lower EUI than the main LMC campus and significantly lower electric emissions due to being associated with PG&Es grid which has a much lower emissions rate of 56 lbs CO2e per MWH of electricity. The facility has an area of 55,000 ft² and was constructed in 2020.

Brentwood Education Center Building Benchmark Data Summary

| Building | Age | Area | EUI | Gas EUI | Total kBTU | Gas kBTU | Elec KBTU | Gas Carbon Emissions (kg CO2) | Electricity Carbon Emissions | Total Carbon Emissions (Kg CO2e) |
|----------------------------|------|--------|------|---------|------------|-----------|-----------|-------------------------------|------------------------------|----------------------------------|
| BRENTWOOD EDUCATION CENTER | 2020 | 54,973 | 64.0 | 29.8 | 34.2 | 3,519,479 | 1,636,712 | 1,882,767 | 191,201 | 30,892 |

Electric Infrastructure Assessment



Electrical Infrastructure Assessment - Introduction

As part of the Electrification Plan, Interface Engineering evaluated the available electrical system capacity at each campus to accommodate the future electrical demands from electrification, renewable energy deployment, and EV charging. The goal of this assessment is to confirm the capacity at the main campus feeders and switchgear. Downstream equipment, such as panels, wiring, and transformers, are not included in this assessment.


We have assessed the available electrical capacity at each of the District's campuses, as well as the District Offices and Brentwood Building. The available capacity has been evaluated using PG&E utility data (15-minute interval data) and PV inverter output data (hourly data provided from the district) for the period of May 2022 through August 2023.

For electrical services that include PV production, the generation data from net generation output (NGOM) meters and/or direct inverter output data is added to the consumption data reported at the main revenue meter, establishing the true demand on the service.

The demand (kW) reported for each service is a calculated value, using the consumption and PV production data (kWh). For example, if 100 kWh are consumed in a 15-min timestep, then the calculated demand for that timestep would be reported as 400 kW (100 kWh X (1/4 hours)).

The chart below shows the energy delivered data from LMC’s main meter. Visual inspection reveals the periods with “real” data vs estimated data.


LMC Main Meter Data




Los Medanos College

- LMC campus is powered by an existing 1200A, 4.16kV service with a total capacity of 8646.6kW. The maximum demand on this service was 1700.5kW.
- LMC's data is from the main revenue meter, seemingly between January 2023 and early August 2023.
 - Peak occurs in September of 2022; therefore it is expected that the missing data is not impacting the projection of peak demand.
- In the missing data period, PG&E has automatically provided an estimated load profile, which causes anomalies in the calculated demand, as seen in March 2023 where demand is shown as negative.
- Demand values include PV system generation data and service consumption data.
- The existing service has an available capacity of 75.4%, or 6520.8kW.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|----------------|
| 1 | Top 0.1% of Demand | 1457.7 kW |
| 2 | Maximum Demand | 1700.5 kW |
| 3 | Maximum Demand Occurrence | 9/6/2022 13:00 |
| 4 | Service Voltage | 4.16 kV |
| 5 | Service Amperage | 1200 A |
| 6 | Service Capacity | 8646.4 kW |
| 7 | Maximum Demand [2] | 1700.5 kW |
| 8 | Maximum Demand * 125% | 2125.6 kW |
| 9 | Available Capacity [6-8] | 6520.8 kW |
| 10 | Percent Available Capacity [9/6] | 75.4% |




Los Medanos College Single Line Diagram




Brentwood

- Brentwood is powered by an existing 1600A, 480V service with a total capacity of 1330.2kW. The maximum demand on this service was 287.4kW.
- Brentwood data appears complete.
- The existing service has an available capacity of 73%, or 971kW.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|----------------|
| 1 | Top 0.1% of Demand | 244.5 kW |
| 2 | Maximum Demand | 287.4 kW |
| 3 | Maximum Demand Occurrence | 9/6/2022 15:15 |
| 4 | Service Voltage | 480 V |
| 5 | Service Amperage | 1600 A |
| 6 | Service Capacity | 1330.2 kW |
| 7 | Maximum Demand [2] | 287.4 kW |
| 8 | Maximum Demand * 125% | 359.2 kW |
| 9 | Available Capacity [6-8] | 971.0 kW |
| 10 | Percent Available Capacity [9/6] | 73.0% |



Brentwood Single Line Diagram



Renewable Energy Deployment



Renewable Energy Deployment Strategy

Introduction

On-site renewable energy generation is a critical component of 4CD’s sustainability plan to achieve net zero carbon emissions by 2035. The district currently has approximately 3.2 MW of photovoltaic (PV) solar panel systems across CCC, DVC, and LMC, which produce nearly 3.8 MWh annually. This represents approximately 19% of the district’s electricity consumption.

As part of its plan to increase on-site renewable production, 4CD has five additional PV projects approved by PG&E for installation but have yet to be funded. For the purposes of estimating the impact of these approved projects, it is assumed that these systems will be installed in 2026. An estimate of the total development costs are shown in the table below, which based on the information provided by Sage Renewables. These costs are based on recent quote that 4CD received for the Brentwood system, which indicated a total cost of \$7.87/watt for carport arrays. The Brentwood, DVC, and LMC installations are also planned to include battery energy storage systems (BESS), which will further enhance the cost reduction capabilities of these systems.

The tables to the right summarize the existing and planned PV systems, including their DC capacity, orientation and expected annual production rate (which vary slightly by campus and by array orientation). The table at the bottom indicates the % of electrical consumption that is met with the existing and future PV systems.

The campus site plans on the subsequent slides indicate the existing and planned PV locations on each campus, including the context of the newly planned buildings as part of the FMP. The site plans also indicate areas that may potentially be used for additional PV in the future.

The energy and carbon impact of the existing and planned arrays are discussed in more detail in the “District Energy and Carbon Timeline” chapter of this report.

The table below shows the future PV, beyond what is currently planned, that would be required in order to achieve net zero emissions for the specific campuses in 2035, and the associated cost of deployment in 2024 PV costs.

| Future PV Summary (Scenario A) | | | | | |
|--------------------------------|-----------|--------------|---------------------------------|--|--------------------------------|
| Campus | Size (kW) | Cost* | Est. Annual Production (kWh/yr) | Predicted Electrical Consumption in 2035 | % Future Load Met by Future PV |
| DVC | 3,844 | \$30,252,280 | 5,766,000 | 8,782,110 | 66% |
| CCC | 2,167** | \$17,054,290 | 3,250,500 | 5,143,509 | 63% |
| LMC | 591 | \$4,651,170 | 886,500 | 4,276,119 | 21% |
| SRC | 433 | \$3,407,710 | 649,500 | 1,413,618 | 46% |
| DO | 468*** | \$3,683,160 | 702,000 | 701,838 | 100% |
| BEC | 166 | \$1,306,420 | 249,000 | 749,521 | 33% |

*costs are based on estimates for PV projects for the district in 2024
**based on offsetting kWh instead of carbon emissions, due to the utility split for CCC between MCE and Constellation
***Due to limited space at this facility, this PV could be installed on another Constellation Campus like DVC, LMC, or SRC to have the same effect.

| Existing PV systems | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | Kwh/KW* | Annual Energy Production (kWh) |
| Contra Costa College - Lot 9 | 403 | 225 | 1053 | 424,359 |
| Diablo Valley College - Lot 1 | 567 | 270 | 1297 | 735,289 |
| Diablo Valley College - Lot 3 | 267 | 270 | 1297 | 346,247 |
| Diablo Valley College - Lot 4 | 548 | 270 | 1297 | 710,650 |
| Los Medanos College - Lot B | 763 | 150 | 1139 | 868,904 |
| Los Medanos College - Lot C | 638 | 230 | 1128 | 719,953 |
| Total | 3,186 | | | 3,805,402 |


*The existing PV production rates are 20-30% below the expected rate, based on the location and orientation of the systems. This may indicate performance issues with the panels and inverters.

| Planned PV systems | | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | kWh/K W | Annual Energy Production (kWh) | Project Development Costs (\$) |
| Diablo Valley College - Lot 5 | 878 | 270 | 1564 | 1,373,000 | \$6,909,860 |
| Contra Costa College - Lot 1 | 947 | 225 | 1551 | 1,469,000 | \$7,452,890 |
| Los Medanos College | 1,154 | 150 | 1560 | 1,800,000 | \$9,081,980 |
| San Ramon Center - Main Lot | 483 | 225 | 1580 | 763,000 | \$3,801,210 |
| Brentwood Center - Main Lot | 322 | 180 | 1556 | 501,032 | \$2,534,140 |
| Total | 3,784 | | | 5,906,032 | \$29,780,080 |

| Renewable Energy Summary | | | | |
|--------------------------|---------------------------------------|----------------------|---------------------|---------------------------|
| | Annual Electricity Consumption (kWh)* | % Met by Existing PV | % Met by Planned PV | Total Planned Renewable % |
| CCC | 4,414,407 | 10% | 33% | 43% |
| DVC | 8,618,555 | 21% | 16% | 37% |
| LMC | 4,783,853 | 33% | 38% | 71% |
| SRC | 1,200,248 | 0% | 64% | 64% |
| Brentwood | 573,479 | 0% | 87% | 87% |
| District Offices | 657,697 | 0% | 0% | 0% |
| District | 20,248,239 | 19% | 28% | 47% |

*True 2022 value that is not weather normalized

Los Medanos College PV Systems



Planned System

- 1,154 KW South of Lot B
- Planned PV offsets ~ 38% of the campus's 2022 electricity

Existing System

- 1,401KW @ parking lot B/C
- Existing PV offsets ~ 33% of the campus's 2022 electricity


Potential Future System

- 591KW @ parking lot A
- Potential PV offsets remaining based on electrical consumption and emissions in 2035 projections
- Approximately 29.5k ft² panel area, based on current PV technology

Brentwood Center PV Systems

Planned System

- 322 KW at Main Lot
- Existing PV offsets ~ 87% of the Brentwood's 2022 electricity



Potential Future System

- 166KW
- Future PV sized based on remaining electrical consumption and emissions in 2035 projections
- Approximately 8.5k ft² panel area, based on current PV technology
- Future location not determined at this time

District Energy Projects



Electrification Plan Introduction

In 2022, more than 48% of the electricity delivered by California's grid was generated by renewable sources such as solar photovoltaics, wind, biomass, and hydroelectric. This percentage will increase over time, as state laws such as SB100 mandate that CA's grid achieve 100% carbon-free generation by 2045. This means that by electrifying legacy natural gas heating systems, the carbon footprint associated with these loads will trend towards zero. For the Contra Costa Community College district in 2022, ~45% of its electricity was provided by renewable resources (including grid-supplied and on-site generation).

The purpose of this study is to support the master-planning effort for the Contra Costa Community College District (4CD) with a district-wide electrification plan. The plan provides an analysis of how electrifying the district's natural gas heating systems and deploying renewable energy systems will reduce the district's energy consumption and carbon footprint.

The primary goal of the electrification plan is to assist the district in meeting its sustainability goals, as outlined in the "2022 4CD District Wide Energy & Sustainability Goals" document.

The electrification plan consists of the following components:

- Building Benchmarking Report
- Electrical Systems Assessment
- Campus Photovoltaic Deployment Assessment.
- Building Electrification Strategy
- District Energy and Carbon Timeline

4CD has adopted a set of sustainability goals which target significant reductions in carbon emissions across the entire organization by 2035. The electrification study addresses the greenhouse gas (GHG) and renewable energy goals by proposing and quantifying the impacts of building replacement and renovation projects, renewable energy systems, as well as additional efficiency projects such as LED lighting, building management controls, metering upgrades and HVAC electrification.

4CD's goals are focused on the two primary dates of 2030 and 2035. The 2030 goals include reducing GHG emissions by 75% below the 2013 baseline and reducing the district energy use intensity (EUI) by 25%. The 2035 goals include reducing GHG emissions by 100% and reducing district EUI by 40%.

HVAC Electrification Strategy

Contra Costa Community College District has adopted a broad set of sustainability goals and practices that will result in dramatic reductions in energy consumption and carbon emissions from its buildings. A key component of these goals is the requirement that all newly constructed buildings are all-electric (no fossil fuel combustion used for space heating). This approach leverages the fact that California's grid is becoming cleaner (emitting less carbon) each year, which inherently reduces the carbon footprint of the campus.

There are a range of all-electric heating technologies that work well for new construction projects. However, converting the existing natural gas heating systems to all-electric has historically been challenging from a technological and financial standpoint. Air-source heat pump (ASHP) technology which use traditional refrigerants have limitations on the temperatures they can produce (typically a maximum supply temperature of approximately 130F), which may make them incompatible with typical legacy heating systems which utilize 160-180F temperatures. The renovations required to make existing buildings compatible with ASHP technology can be prohibitively expensive. These renovations may require replacement of some heating coils to accommodate lower water temperature, and often piping/coupling systems need to also be replaced. Furthermore, ASHP technology is limited to a lower ambient temperature of ~25F, which means that supplemental heating may be required on the coldest days of the year.

Water-source heat pumps (WSHP) are more flexible, with supply temperatures as high as 170F. These require a water-based heat source/sink, such as a ground loop via a geo-exchange system. Geo-exchange systems are often very costly due to the cost of drilling vertical wells or excavating for horizontal systems. These costs and space constraints typically preclude water-source heat pumps as a retrofit solution.

Transcritical heat pump (TCHP) technology is relatively new to building comfort heating and cooling which is addressing the traditional challenges of ASHPs and WSHPs. This technology utilizes CO₂ as its refrigerant (known as R744), which enables hot water delivery temperatures of 180F at outdoor ambient conditions down to -15F. This allows "direct replacement" of natural gas boilers and domestic hot water heaters. This technology is still "emerging", with a limited number of installations in the U.S., however, it is expected that this technology will develop rapidly over the next 5 years.

For existing buildings with traditional boiler-based hydronic systems, an assessment process is recommended to determine what modifications are required in order to electrify these systems with the highest possible efficiency. The primary goal of this assessment is to determine if the existing hydronic systems is capable of operating at lower heating hot water temperatures while still maintaining design temperatures. Lowering the hot water temperatures allows for compatibility with a wider range of heat pump technology, and also allows them to operate much more efficiently. The following bullet points outline the assessment process:

- Review heating coils configuration - heating coil performance will be reduced when operating at lower hot water temperatures, however, in some cases, this performance derating can be overcome with modification to control sequences. In most cases, two-row heating coils at air handling units and VAV boxes can be utilized when lowering hot water temperatures from 180F to 140F, or even lower. The peak capacity of the coils is reduced with lower water temperatures, but simply increasing the warm-up time of the building may overcome these limitations. Also, reducing the temperature setback of the space will reduce the load that the coils must meet. Single-row coils will likely struggle to meet the load with reduced water temperatures and may need to be replaced.
- Conduct a hot water reset investigation – During the winter months, reduce the heating hot water temperature in 5-degree increments for one to two weeks at a time. This process will reveal which zones/coils are able to meet space loads with reduced water temperatures. As zones are discovered to be out of setpoint, increase the warm-up period or limit the temperature setback. Continue to reduce water temperatures and increase warmup period to determine if a lower water temperature will allow the building to maintain functionality. This process may reveal that certain zones/coils will function adequately, while others may need to be upgraded. The desired outcome of the reset investigation is a custom outdoor air reset control sequence that reduces hot water temperatures to a minimum, as a function of outside air temperature. For example, the goal may be to operate at 140F supply/ 100F return as often as possible but allows for increases up to 180F supply / 140F return on the coldest days of the year.

HVAC Electrification Strategy

Transcritical Heat Pumps

While this heat pump technology has long been used in commercial refrigeration for 20 years or more, it is more recently being applied to building HVAC and domestic hot water. Typically, these machines use CO₂, or R-744, as its refrigerant, which has a global warming potential (GWP) of 1, which is far below traditional refrigerants like R-410a (GWP of 2088) or R-134a (GWP of 1430). Furthermore, R-744 is able to operate with much higher temperatures, at or above 180F. However, like traditional heat pumps, transcritical heat pumps operate much more efficiently with lower supply water temperatures.

As the technology continues to advance, it may become a critical component of electrifying existing buildings that utilize hydronic heating. The graph on the right shows the efficiency curves for various operating conditions for Flow Environmental System’s model H transcritical heat pump. These trends show that while operating at “traditional” boiler system temperatures of 180F supply / 140F return, a COP of 1.75 is achieved. However, lowering the supply temperature to 140F dramatically improves efficiency, approaching a COP of 3.5. This highlights the importance of the hot water reset assessment process outline on the previous page.


Transcritical heat pump technology is also well suited for domestic hot water applications, where storage temperatures typically range from 125F – 140F. Systems like Sanden and Lync are able to achieve COPs above 5, which allows for significant improvements to operation cost and carbon emissions associated with domestic hot water.

The links below are examples of transcritical heat pump technology that are recommended for investigation by future design teams for use in both new construction and retrofit projects.

<https://www.flowenvirosys.com/products>

<https://www.smallplanetsupply.com/sanc02>

<https://www.lyncbywatts.com/>



HVAC Electrification Strategy

Central Plant Opportunities


An all-electric central utility plant (CUP) may be an effective strategy to employ as part of the early FMP projects. At Los Medanos College, the newly planned Health Sciences building is one of the first major projects that will occur within the core of the campus. It is in relatively close proximity to several other newly planned or renovated building. A central plant can be designed and planned at the new Health Sciences building with the intent to expand over time, as new buildings are built, and existing buildings are retrofitted.

For Contra Costa College, a central plant may be feasible as part of the renovation of Student Services or General Education buildings. However, space constraints may make this challenging.

For Diablo Valley College, a central plant may be feasible as part of the new academic complex, which is planned for construction in 2030. this central plant could then be available to serve the renovation projects as they occur in the later 2030's.


Utilizing a central plant, as opposed to each building having standalone heating and cooling equipment, offers many benefits in terms of efficiency, redundancy, and heat recovery. Centralizing the load of multiple buildings offers diversity in the load profile, which may allow for energy to be recovered (using heat recovery heat pumps) when simultaneous heating and cooling loads are required across a campus. Central plant equipment can be designed with proper modularity to allow for very efficient part load operation, as well as inherent redundancy. Thermal storage systems can be readily added to a central plant, allowing primary heating and cooling equipment to be dramatically downsized, as well as offering the ability to load shift to times when energy is cheap or when the grid is the cleanest (depending on District priority).

The downsides of a central plant approach are primarily cost and complexity. A significant infrastructure investment is required to install the initial phases of a central plant, sizing piping and electrical systems for their anticipated future loads. However, future buildings that connect to the central plant will be lower cost. The equipment is typically of a larger scale, often requiring specialized contractors to perform major maintenance. A relatively large area is often required to house the central plant equipment, which can be challenging for some campuses.



HVAC Electrification Strategy

Los Medanos College



HVAC Electrification Strategy

Los Medanos College – FMP Projects Pt.1: New

The 2024 Facilities Master Plan identifies 10 projects (new construction and renovation) that will enhance the usability of the campus and increase building efficiency. The new construction projects consist of 7 new buildings. 4 of them are planned to occur within a period that impacts the energy timeline, and 3 are planned to occur outside of that period.

As part of the 4CD sustainability goals, each of these new buildings will be all-electric and LEED gold certified. The predicted EUI of these buildings is shown in the table below, along with the assumptions of building size and what year the projects will be built.

| New Construction Projects | | | | | |
|------------------------------------|------------|----------------------|----------------------------|--------------------------------------|---|
| Building | Area (ft2) | Year of Construction | Predicted EUI (kBtu/sf-yr) | Annual Electricity Consumption (kWH) | Notes |
| New Administrative Building | 30,000 | 2034 | 28 | 246,180 | Coincides with FMP demolition of Core Building |
| New Child Study Center | 18,000 | 2027 | 25 | 131,882 | Same year as old child study center converted to welcome center |
| New Health Sciences | 36,000 | 2029 | 35 | 369,270 | |
| New Interdisciplinary Lab Building | 46,000 | 2032 | 45 | 606,657 | |

- Projects that are expected to occur further in the future are:
1. New Gymnasium
 2. New General Academic Building
 3. New Athletic Stadium

HVAC Electrification Strategy

Los Medanos College – FMP Projects Pt.2

The 2024 Facilities Master Plan identifies 10 projects that will enhance the usability of the campus. These projects include 3 renovations, 2 of which occur during the timeline of the energy study.

Renovation projects are anticipated to eliminate natural gas from the HVAC and plumbing systems, resulting in a substantial energy and carbon emissions reduction. These savings are summarized in the table below.

| Renovation Projects | | | | | | | |
|---------------------|------------|--------------------|--------------|----------------------------|------------------------------|----------------------------|--|
| Building | Area (ft2) | Year of Renovation | Existing EUI | Predicted EUI (kBtu/sf-yr) | Natural Gas Reduction (kBtu) | Electricity Reducton (kWh) | Notes |
| COLLEGE COMPLEX | 148,126 | 2034 | 101.3 | 56.2 | 7,201,930 | 1,679,606 | 75% of building demolished and ALC/LED/Electrification Included |
| CHILD STUDY CENTER | 13,197 | 2027 | 85.0 | 45.5 | 527,497 | 42,397 | 25% of building demolished and ALC/LED/Electrification for remainder |

Renovations of the following buildings occur after and outside our energy timeline:
Student Services

HVAC Electrification Strategy

Los Medanos College– Additional Efficiency Projects

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|-------------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|--|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| LIBRARY | 34,677 | 2026 | | x | x (Boiler) | Boiler at end of life, AHUs close | | \$568,022 | \$1,136,045 | \$1,704,067 | -58,852 | 893,366 | 44.0 | 24.0 |
| MATH | 23,009 | 2034 | | x | x (Boiler) | Boiler has 14 years left, renovation recommended at 10 years for climate goals | | \$535,984 | \$1,071,968 | \$1,607,952 | -54,553 | 740,890 | 61.6 | 37.5 |
| SCIENCE | 51,469 | 2025 | x | | x (Boiler) | AHUs have 4 years left, boilers not in inventory | \$537,851 | | \$1,613,553 | \$2,151,404 | 22,023 | 1,297,019 | 55.4 | 28.8 |
| KINESIOLOGY/ATHLETICS COMPLEX | 30,153 | 2028 | | x | x (Boiler) | Hot water provided by 400 MBH commercial water heater with 16 years useful remaining life per BV | | \$539,370 | \$1,078,740 | \$1,618,111 | -51,242 | 777,465 | 42.4 | 22.4 |
| STUDENT UNION | 29,017 | 2034 | | x | x (Boiler) | Boiler has 11 years left, AHU has 16 | | \$675,938 | \$1,351,875 | \$2,027,813 | -75,448 | 997,883 | 72.0 | 46.5 |
| GYM | 19,940 | 2025 | | x | x (Boiler) | Roof AHU at end of life, same boiler as science, so same year | | \$312,560 | \$625,119 | \$937,679 | -49,773 | 665,916 | 48.2 | 23.3 |
| MUSIC ADDITION | 13,345 | 2026 | x | x | x (Furnace) | Furnaces one year away from end of life | \$145,731 | \$218,596 | \$364,327 | \$728,654 | 6,923 | 470,812 | 83.2 | 47.5 |


*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.

HVAC Electrification Strategy

Los Medanos College– District Energy Project Savings and Cost Summary

| District Energy Projects Cumulative Cost | | | | District Energy Project Annual Cost Savings (2023 LMC Utility Rates) | | | | |
|--|-------------|-----------------|--------------|--|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting | Controls | Electrification | Total | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| \$683,582 | \$2,850,470 | \$7,241,628 | \$10,775,679 | \$47,685 | \$36,011 | \$115,698 | -\$146,787 | \$52,608 |

| District Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | | District Energy Project Annual Cost Savings (2035 Estimated LMC Utility Rates) | | | | |
|---|--------------------------|----------------------------|----------------------------|--|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| 677,954 | 511,981 | 3,756,440 | 5,843,351 | \$85,155 | \$64,308 | \$206,610 | -\$262,128 | \$93,945 |




HVAC Electrification Strategy


Los Medanos College– District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. In this graph it is clear that PV offers a majority of the emissions reduction in the short term and electrification has less impact, for a relatively higher price. However, as the grid becomes cleaner, the impact of PV and other electrical consumption decreases, and the remaining gas emissions become a dominant source of emissions that is hard to offset. Electrification is also very important for meeting the campus building EUI targets.

Metric Tons of CO2 Averted, by Measure



Emissions Averted from 2026 to 2040 (15 Years - Metric Tons of CO2)



HVAC Electrification Strategy

Brentwood Education Center – Additional Efficiency Projects

The following matrix outlines the electrification planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|----------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|---|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| BRENTWOOD EDUCATION CENTER | 54,973 | 2034 | | | X (Boiler) | Unknown boiler age, but it is a new boiler since building was constructed in 2020 | | | \$2,561,142 | \$2,561,142 | -171,312 | 1,636,712 | 64.0 | 44.9 |

*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWH.

HVAC Electrification Strategy

Brentwood Education Center – District Energy Project Savings and Cost Summary

| BEC Energy Projects Cumulative Cost | | | |
|-------------------------------------|-------------|-----------------|-------------|
| Lighting | Controls | Electrification | Total |
| \$953,678 | \$1,430,517 | \$2,561,142 | \$4,945,337 |

| BEC Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | |
|--|--------------------------|----------------------------|----------------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) |
| 0 | 0 | 1,052,172 | 1,636,712 |

| 2023 BEC Energy Project Energy Cost Savings (Annual Impact - Not Cumulative) | | | | |
|--|------------------|----------------------------------|-----------------------------|----------------------|
| Lighting Savings | Controls Savings | Electrification Electric Penalty | Electrification Gas Savings | Total Annual Savings |
| \$0 | \$0 | -\$92,508 | \$35,517 | -\$56,992 |


| 2035 BEC Energy Project Energy Cost Savings (Annual Impact - Not Cumulative) | | | | |
|--|------------------|----------------------------------|-----------------------------|----------------------|
| Lighting Savings | Controls Savings | Electrification Electric Penalty | Electrification Gas Savings | Total Annual Savings |
| \$0 | \$0 | -\$165,198 | \$63,424 | -\$101,774 |

All of the Brentwood Education Cener projects are scheduled for 2034.

HVAC Electrification Strategy

Brentwood Education Center– District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. PV provides a low amount of offset emissions, due to Brentwood’s lower emitting electric utility, so the majority of emissions averted come from the electrification project. The planned PV has a more significant impact on the operational costs of the campus, relative to its small emissions impact.



Energy Timeline




HVAC Electrification Strategy

Los Medanos College– Campus EUI Trend

The EUI of the LMC campus is very sensitive to the high gas use associated with the college complex. This means that there will be a large EUI reduction when large portions of the college complex building are demolished. With this work planned for 2034, the 2035 EUI goal is much more achievable than the 2030 EUI goal. Overall, electrification is very important to achieving campus EUI and emissions goals, as large reductions in gas kBTU results in much smaller increases in electric kBTU.

Campus EUI (kBTU/sf-yr) by Type (Renewables Excluded)




HVAC Electrification Strategy

Los Medanos College– Campus Utility Costs Trend

The chart below shows the total and fuel specific utility costs for the campus going forwards. This is based on an assumption of a 4% escalation of electricity and gas costs per year, as well as the campus being in a net metering scheme which allows for the PV kWh to have the same value as electric consumption kWh. The 2022 use with escalated electricity and gas costs are also shown with a dotted line, to show the impact of the cumulative interventions performed on the campus. Renewables and efficiency upgrades like controls and LEDs reduce the operating cost of the campus. In this case, the planned renewables and demolition/renovation of the college complex both cause a significant reduction in the operating costs for the facility. The 0.591 MW of additional future PV required to offset emissions by 2035 would result in an estimated additional \$380,000 a year of cost savings with 2035 utility rates.

Campus Energy Cost over Time (Dollars)




Planned PV is assumed to be installed in the year prior to the start of 2026.

HVAC Electrification Strategy

Los Medanos College– Campus Emissions Trend


The graph below shows the emissions trend accounting FMP and non-FMP projects. Emissions offset by renewables depreciate over time due to decreasing grid emissions. Emissions from electrical consumption depreciate at the same rate. The starting emissions are based on weather normalized data. Even with these projects, a moderate amount of carbon would still need to be offset to reach net zero by 2035. If this takes the form of PV, 591 kW of additional PV capacity beyond what is currently planned would be needed to reach net zero emissions by 2035. Otherwise, to meet the goal, offsets would need to be purchased until the California grid is legislated to be emissions free by 2045. This amount would start at about 175 tons per year in 2035 and decrease to 87 tons per year by 2040 as the grid approaches the legislative targets. If the CA grid/Constellation emissions rate approaches zero carbon faster or slower than legislatively required, the offsets required could go up or down. A good efficiency and emissions reduction strategy may not require each individual campus to meet the sustainability goals, but rather the ensemble of campuses meeting the goals. This will allow for taking advantage of deploying PV where it is most effective (campuses associated with higher emitting utilities) or where there is the most capacity, and purchasing offsets or clean energy at a district level for the net emissions that remain.




HVAC Electrification Strategy

Brentwood Education Center - Energy and Emissions Information

Information regarding Brentwood Education Center PV and its role in the overall campus emissions and EUI reduction will be included in the district wide version of the report. Below are graphs of the EUI and emissions of the facility over time, without goals or PV/Carbon Offset/Purchased Green Energy interventions. We have also included data for an electrification project associated with Brentwood Education center. Due to Brentwood's very low electric grid emissions rate, electrification can have an extreme impact on its emissions.




| Brentwood Education Center Electrification | | | | | | | |
|--|------|-------------|--------------|-----------|-----------------------|--------------------|------------------------------------|
| Area | Year | Cost | Starting EUI | EUI After | Electric kWh Increase | Gas kBTU reduction | Annual Cost Penalty (2034 Dollars) |
| 54,973 | 2034 | \$2,561,142 | 64 | 45 | 584,540 | 1,636,712 | \$24,442 |



HVAC Electrification Strategy

Brentwood Education Center – Facility Utility Costs Trend

The chart below shows the total and fuel specific utility costs for the BEC campus going forwards. This is based on an assumption of a 4% escalation of electricity and gas costs per year, as well as the campus being in a net metering scheme which allows for the PV kWh to have the same value as electric consumption kWh. The 2022 use with escalated electricity and gas costs are also shown with a dotted line, to show the impact of the cumulative interventions performed on the campus. Renewables reduce the operating cost of the campus. The 166 kW of additional PV required to offset emissions by 2035 would result in an estimated additional 133 thousand dollars a year of cost savings with 2035 utility rates.




Planned PV is assumed to be installed in the year prior to the start of 2026.

HVAC Electrification Strategy

Brentwood Education Center– Campus Emissions Trend

The graph below shows the emissions trend accounting FMP and non-FMP projects. Emissions offset by renewables deprecate over time due to decreasing grid emissions. The extreme drop in emissions is associated with the electrification of the facility in 2034. The emissions rate for the utility serving the center is low, and because of this, there is a drastic reduction in emissions from electrification. The campus would need 166 additional kW of PV to offset its emissions completely in 2035.



2.

Contra Costa College

Carbon and Energy Benchmarking



Building Benchmarking Study - Introduction


As part of the District Sustainability and Electrification plan, the portfolio of campus buildings has been subject to a benchmarking study to attempt to determine the highest priority target buildings for electrification and chart a path for the district towards meeting its sustainability goals. The data used for this benchmarking study consists of engineering and architectural drawings provided by the community college district, campus wide electricity and gas usage data, and results from a building equipment and facilities audit performed by Bureau Veritas. Building EUIs were also adjusted based on known operational configurations for particular campuses and buildings, as well as the mechanical and air systems.

Electricity and gas usage was estimated for each individual building on the campus based on available benchmarking data by building type for the bay area climate zones, the state of California as a whole, and available campus wide billing data. These estimates were then adjusted based on known building specific characteristics. Large multi-purpose campus buildings were divided into the various use-types they are composed of in order to provide an accurate EUI estimate for the building, as well as a use-type specific EUI for that campus.

The estimates were then revised based on a dialogue with the district on the values, particular building meter data, multi-building line meter data, and site electricity data that was made available.


The energy and carbon impact of the pools were estimated based on available boiler data for the Contra Costa College pool and then a gas usage per square foot per year was applied to the Diablo Valley College pool in order to estimate the portion of the gas usage that is not part of a building EUI.

Building type energy data from the bay area, California, and the United States came from the [Lawrence Berkley National Laboratory Building Performance Database](#) and was adjusted or compiled into campus use types based on engineering judgement.




Sample BPD Query

The Energy Star [Commercial Buildings Energy Consumption Survey](#) and data from the [Higher Education Benchmarking Initiative](#) were also used to estimate end-use breakdowns and as a comparison point for realistic data for particular types of campuses.




Sample CBECs Data

CCC 2022 Weather Normalized Campus EUI (kBtu/sf)



■ Building Elec EUI ■ Site Elec EUI ■ Building Gas EUI ■ Pool Gas EUI

CCC 2022 Weather Normalized Campus Emissions Breakdown




■ Total Building Elec Emissions ■ Total Site Elec Emissions
■ Total Building Gas Emissions ■ Total Pool Gas Emissions

CCC

Campus-Level Benchmarking

The campus EUI graph sums the total gas and electricity associated with the campus and divides them by the square footage of campus buildings included in the EUI study. The breakdown is representative of the split between gas and electricity use on the campus. The campus emissions chart shows the portion of the campuses total emissions that are associated with each fuel type. This data is all based on weather normalized data for the gas and electricity use and does not exactly match the real quantities but is better for a forward-looking analysis of the campus energy. CCC electricity use is associated with a mix of Constellation energy which as a grid emissions rate of 701 lbs CO₂e per MWH of electricity and MCE which has a grid emissions rate of 44 lbs CO₂e per MWH of electricity. This results in an average campus emissions rate of 175 lbs CO₂e per MWH of electricity. The low emissions rate for the grid here means that a majority of the emissions for the campus come from gas use. The area for EUI calculations in 2022 was 467,113 ft².


CCC Campus Area Breakdown (Percent)



CCC

Campus Program Breakdown


The campus area breakdown shows the portion of the campus square footage associated with each of the program type categories in our study. Buildings with multiple use types have had their square footage distributed proportionally.



CCC

EUI per Program Type

The program EUIs are based on the weighted average of individual EUIs of buildings in each program classification, which may vary. These programs were assigned for energy analysis purposes and may not match other campus program breakdowns.




CCC

Energy Breakdown by Building

*Some buildings with negligible energy use are excluded from this graph

Total Carbon Emissions (Kg C02e)



CCC

Total Emissions

CCC Benchmark Data Summary Table

| Building | Age | Area | EUI | Gas EUI | Electric EUI | Total kBTU | Gas kBTU | Elec kBTU | Gas Carbon Emissions (metric tons CO2) | Electricity Carbon Emissions (metric tons CO2) | Total Carbon Emissions (metric tons CO2) |
|--|------|--------|------|---------|--------------|------------|-----------|-----------|--|--|--|
| STUDENT & ADMINISTRATION | 2016 | 53,577 | 71.9 | 36.4 | 35.5 | 3,854,501 | 1,952,641 | 1,901,860 | 104 | 44 | 148 |
| GENERAL EDUCATION BLDG | 2016 | 51,234 | 69.0 | 35.9 | 33.1 | 3,534,736 | 1,841,247 | 1,693,489 | 98 | 40 | 137 |
| VOC ARTS/COMPUTER TECH | 1957 | 30,912 | 78.8 | 41.2 | 37.6 | 2,434,796 | 1,272,035 | 1,162,761 | 68 | 27 | 95 |
| APPLIED ARTS & ADM. | 1982 | 50,000 | 52.4 | 21.3 | 31.1 | 2,618,000 | 1,063,650 | 1,554,350 | 56 | 36 | 93 |
| SCIENCE CENTER | 2021 | 54,965 | 56.3 | 2.9 | 53.4 | 3,094,023 | 160,484 | 2,933,539 | 9 | 69 | 77 |
| LIBRARY | 1963 | 32,904 | 54.0 | 31.8 | 22.2 | 1,777,556 | 1,045,915 | 731,641 | 56 | 17 | 73 |
| GYM ANNEX | 1969 | 36,327 | 44.2 | 32.2 | 11.9 | 1,603,934 | 1,170,611 | 433,323 | 62 | 10 | 72 |
| PERFORMING ARTS CENT | 1980 | 21,000 | 68.1 | 50.8 | 17.4 | 1,430,444 | 1,065,926 | 364,518 | 57 | 9 | 65 |
| ART | 1971 | 15,900 | 96.8 | 57.5 | 39.3 | 1,538,611 | 913,550 | 625,061 | 49 | 15 | 63 |
| STUDENT SERVICES | 2008 | 19,280 | 68.3 | 39.6 | 28.7 | 1,316,378 | 763,183 | 553,196 | 41 | 13 | 53 |
| MUSIC | 1964 | 14,522 | 89.6 | 52.4 | 37.2 | 1,301,171 | 760,372 | 540,799 | 40 | 13 | 53 |
| GYMNASIUM | 1957 | 22,551 | 46.1 | 26.9 | 19.1 | 1,038,512 | 606,985 | 431,527 | 32 | 10 | 42 |
| LOCKER ROOM BUILDING | 1957 | 8,732 | 73.9 | 55.5 | 18.4 | 645,431 | 484,578 | 160,853 | 26 | 4 | 29 |
| MAINT/POLICE OFFICES | 1967 | 6,570 | 88.1 | 53.0 | 35.1 | 578,795 | 348,032 | 230,763 | 18 | 5 | 24 |
| EARLY LEARNING CENTER | 2003 | 14,504 | 50.4 | 1.3 | 49.1 | 731,002 | 18,275 | 712,727 | 1 | 17 | 18 |
| ATHLETIC TRAINING AND KINESIOLOGY CENTER | 1962 | 4,531 | 53.9 | 40.0 | 13.9 | 244,221 | 181,122 | 63,099 | 10 | 1 | 11 |
| FIRESIDE HALL | 2016 | 3,590 | 68.7 | 45.8 | 23.0 | 246,781 | 164,306 | 82,475 | 9 | 2 | 11 |
| MAINTENANCE SHOPS | 1959 | 5,636 | 21.0 | 12.9 | 8.1 | 118,217 | 72,775 | 45,442 | 4 | 1 | 5 |
| CAMPUS POLICE/SAFETY CENTER | 2019 | 3,430 | 50.4 | 0.0 | 50.4 | 172,872 | 0 | 172,872 | 0 | 4 | 4 |
| WL PORTABLE | 2022 | 2,100 | 59.5 | 0.0 | 59.5 | 124,950 | 0 | 124,950 | 0 | 3 | 3 |
| ML PORTABLE | 2022 | 2,100 | 59.5 | 0.0 | 59.5 | 124,950 | 0 | 124,950 | 0 | 3 | 3 |
| CUSTODIAL OFFICES | 1998 | 1,392 | 75.6 | 1.3 | 74.3 | 105,235 | 1,754 | 103,481 | 0 | 2 | 3 |
| AUTO COMPRESSOR BLDG | 1997 | 300 | 14.3 | 0.3 | 14.0 | 4,275 | 90 | 4,185 | 0 | 0 | 0 |
| REFEREE TRAILER | 2000 | 300 | 10.0 | 0.0 | 10.0 | 3,000 | 0 | 3,000 | 0 | 0 | 0 |

The pool uses 2,460,000 kBTU per year, or about 177 kBTU/sf/yr, and is associated with the same boiler as the gym annex building.



Electric Infrastructure Assessment



Electrical Infrastructure Assessment - Introduction

As part of the Electrification Plan, Interface Engineering evaluated the available electrical system capacity at each campus to accommodate the future electrical demands from electrification, renewable energy deployment, and EV charging. The goal of this assessment is to confirm the capacity at the main campus feeders and switchgear. Downstream equipment, such as panels, wiring, and transformers, are not included in this assessment.

We have assessed the available electrical capacity at each of the District's campuses, as well as the District Offices and Brentwood Building. The available capacity has been evaluated using PG&E utility data (15-minute interval data) and PV inverter output data (hourly data provided from the district) for the period of May 2022 through August 2023.

For electrical services that include PV production, the generation data from net generation output (NGOM) meters and/or direct inverter output data is added to the consumption data reported at the main revenue meter, establishing the true demand on the service.


The demand (kW) reported for each service is a calculated value, using the consumption and PV production data (kWh). For example, if 100 kWh are consumed in a 15-min timestep, then the calculated demand for that timestep would be reported as 400 kW (100 kWh X (1/4 hours)).

Contra Costa College (New Service)


- CCC's New MV Loop, that serves a majority of the campus, is powered by an existing 200A, 12kV service with a total capacity of 4156.9kW. The maximum demand on this service was 10007.4kW.
- Demand data for the "New MV Loop" is mostly complete. There is a missing period of data around November of 2022, but the peak demand is not expected to occur in this period.
- Demand values include PV system generation data and service consumption data.
- The existing service has an available capacity of 69.7%, or 2897.7kW.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|----------------|
| 1 | Top 0.1% of Demand | 905.1 kW |
| 2 | Maximum Demand | 1007.4 kW |
| 3 | Maximum Demand Occurrence | 9/6/2022 13:00 |
| 4 | Service Voltage | 12 kV |
| 5 | Service Amperage | 200 A |
| 6 | Service Capacity | 4156.9 kW |
| 7 | Maximum Demand [2] | 1007.4 kW |
| 8 | Maximum Demand * 125% | 1259.3 kW |
| 9 | Available Capacity [6-8] | 2897.7 kW |
| 10 | Percent Available Capacity [9/6] | 69.7% |

CCC Demand Profile
New MV Loop




Contra Costa College (New Service) Single Line Diagram




Contra Costa College (Old Service)

- CCC's Old MV Loop, that serves the sports and field of the campus, is powered by an existing 600A, 12kV service with a total capacity of 12470.8kW. The maximum demand on this service was 269.8kW.
- CCC old service data appears complete.
- The existing service has an available capacity of 97.3%, or 12133.6kW. This service appears to be under-utilized.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|----------------|
| 1 | Top 0.1% of Demand | 252.3 kW |
| 2 | Maximum Demand | 269.8 kW |
| 3 | Maximum Demand Occurrence | 3/1/2023 18:30 |
| 4 | Service Voltage | 12 kV |
| 5 | Service Amperage | 600 A |
| 6 | Service Capacity | 12470.8 kW |
| 7 | Maximum Demand [2] | 269.8 kW |
| 8 | Maximum Demand * 125% | 337.2 kW |
| 9 | Available Capacity [6-8] | 12133.6 kW |
| 10 | Percent Available Capacity [9/6] | 97.3% |



Contra Costa College (Old Service) Single Line Diagram



Renewable Energy Deployment



Renewable Energy Deployment Strategy

Introduction

On-site renewable energy generation is a critical component of 4CD’s sustainability plan to achieve net zero carbon emissions by 2035. The district currently has approximately 3.2 MW of photovoltaic (PV) solar panel systems across CCC, DVC, and LMC, which produce nearly 3.8 MWh annually. This represents approximately 19% of the district’s electricity consumption.

As part of its plan to increase on-site renewable production, 4CD has five additional PV projects approved by PG&E for installation but have yet to be funded. For the purposes of estimating the impact of these approved projects, it is assumed that these systems will be installed in 2026. An estimate of the total development costs are shown in the table below, which based on the information provided by Sage Renewables. These costs are based on recent quote that 4CD received for the Brentwood system, which indicated a total cost of \$7.87/watt for carport arrays. The Brentwood, DVC, and LMC installations are also planned to include battery energy storage systems (BESS), which will further enhance the cost reduction capabilities of these systems.

The tables to the right summarize the existing and planned PV systems, including their DC capacity, orientation and expected annual production rate (which vary slightly by campus and by array orientation). The table at the bottom indicates the % of electrical consumption that is met with the existing and future PV systems.

The campus site plans on the subsequent slides indicate the existing and planned PV locations on each campus, including the context of the newly planned buildings as part of the FMP. The site plans also indicate areas that may potentially be used for additional PV in the future.

The energy and carbon impact of the existing and planned arrays are discussed in more detail in the “District Energy and Carbon Timeline” chapter of this report.

The table below shows the future PV, beyond what is currently planned, that would be required in order to achieve net zero emissions for the specific campuses in 2035, and the associated cost of deployment in 2024 PV costs.

| Future PV Summary (Scenario A) | | | | | |
|--------------------------------|-----------|--------------|---------------------------------|--|--------------------------------|
| Campus | Size (kW) | Cost* | Est. Annual Production (kWh/yr) | Predicted Electrical Consumption in 2035 | % Future Load Met by Future PV |
| DVC | 3,844 | \$30,252,280 | 5,766,000 | 8,782,110 | 66% |
| CCC | 2,167** | \$17,054,290 | 3,250,500 | 5,143,509 | 63% |
| LMC | 591 | \$4,651,170 | 886,500 | 4,276,119 | 21% |
| SRC | 433 | \$3,407,710 | 649,500 | 1,413,618 | 46% |
| DO | 468*** | \$3,683,160 | 702,000 | 701,838 | 100% |
| BEC | 166 | \$1,306,420 | 249,000 | 749,521 | 33% |

*costs are based on estimates for PV projects for the district in 2024
**based on offsetting kWh instead of carbon emissions, due to the utility split for CCC between MCE and Constellation
***Due to limited space at this facility, this PV could be installed on another Constellation Campus like DVC, LMC, or SRC to have the same effect.

| Existing PV systems | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | Kwh/KW* | Annual Energy Production (kWh) |
| Contra Costa College - Lot 9 | 403 | 225 | 1053 | 424,359 |
| Diablo Valley College - Lot 1 | 567 | 270 | 1297 | 735,289 |
| Diablo Valley College - Lot 3 | 267 | 270 | 1297 | 346,247 |
| Diablo Valley College - Lot 4 | 548 | 270 | 1297 | 710,650 |
| Los Medanos College - Lot B | 763 | 150 | 1139 | 868,904 |
| Los Medanos College - Lot C | 638 | 230 | 1128 | 719,953 |
| Total | 3,186 | | | 3,805,402 |

*The existing PV production rates are 20-30% below the expected rate, based on the location and orientation of the systems. This may indicate performance issues with the panels and inverters.

| Planned PV systems | | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | kWh/K W | Annual Energy Production (kWh) | Project Development Costs (\$) |
| Diablo Valley College - Lot 5 | 878 | 270 | 1564 | 1,373,000 | \$6,909,860 |
| Contra Costa College - Lot 1 | 947 | 225 | 1551 | 1,469,000 | \$7,452,890 |
| Los Medanos College | 1,154 | 150 | 1560 | 1,800,000 | \$9,081,980 |
| San Ramon Center - Main Lot | 483 | 225 | 1580 | 763,000 | \$3,801,210 |
| Brentwood Center - Main Lot | 322 | 180 | 1556 | 501,032 | \$2,534,140 |
| Total | 3,784 | | | 5,906,032 | \$29,780,080 |


| Renewable Energy Summary | | | | |
|--------------------------|---------------------------------------|----------------------|---------------------|---------------------------|
| | Annual Electricity Consumption (kWh)* | % Met by Existing PV | % Met by Planned PV | Total Planned Renewable % |
| CCC | 4,414,407 | 10% | 33% | 43% |
| DVC | 8,618,555 | 21% | 16% | 37% |
| LMC | 4,783,853 | 33% | 38% | 71% |
| SRC | 1,200,248 | 0% | 64% | 64% |
| Brentwood | 573,479 | 0% | 87% | 87% |
| District Offices | 657,697 | 0% | 0% | 0% |
| District | 20,248,239 | 19% | 28% | 47% |

*True 2022 value that is not weather normalized

Contra Costa College PV Systems

Planned System

- 947 KW at Lot 1
- Planned PV offsets ~ 33% of the campus's 2022 electricity consumption



Potential Future System

- Potential PV offsets remaining based on projected electrical consumption in 2035
- 2.682 MW required, approximately 134k ft² panel area, based on current PV technology (future location not determined at this time).

Existing System

- 403KW @ parking lot 9/10
- Existing PV offsets ~ 10% of the campus's 2022 electricity consumption

District Energy Projects



Electrification Plan Introduction

In 2022, more than 48% of the electricity delivered by California's grid was generated by renewable sources such as solar photovoltaics, wind, biomass, and hydroelectric. This percentage will increase over time, as state laws such as SB100 mandate that CA's grid achieve 100% carbon-free generation by 2045. This means that by electrifying legacy natural gas heating systems, the carbon footprint associated with these loads will trend towards zero. For the Contra Costa Community College district in 2022, ~45% of its electricity was provided by renewable resources (including grid-supplied and on-site generation).

The purpose of this study is to support the master-planning effort for the Contra Costa Community College District (4CD) with a district-wide electrification plan. The plan provides an analysis of how electrifying the district's natural gas heating systems and deploying renewable energy systems will reduce the district's energy consumption and carbon footprint.

The primary goal of the electrification plan is to assist the district in meeting its sustainability goals, as outlined in the "2022 4CD District Wide Energy & Sustainability Goals" document.

The electrification plan consists of the following components:

- Building Benchmarking Report
- Electrical Systems Assessment
- Campus Photovoltaic Deployment Assessment.
- Building Electrification Strategy
- District Energy and Carbon Timeline

4CD has adopted a set of sustainability goals which target significant reductions in carbon emissions across the entire organization by 2035. The electrification study addresses the greenhouse gas (GHG) and renewable energy goals by proposing and quantifying the impacts of building replacement and renovation projects, renewable energy systems, as well as additional efficiency projects such as LED lighting, building management controls, metering upgrades and HVAC electrification.

4CD's goals are focused on the two primary dates of 2030 and 2035. The 2030 goals include reducing GHG emissions by 75% below the 2013 baseline and reducing the district energy use intensity (EUI) by 25%. The 2035 goals include reducing GHG emissions by 100% and reducing district EUI by 40%.

HVAC Electrification Strategy

Contra Costa Community College District has adopted a broad set of sustainability goals and practices that will result in dramatic reductions in energy consumption and carbon emissions from its buildings. A key component of these goals is the requirement that all newly constructed buildings are all-electric (no fossil fuel combustion used for space heating). This approach leverages the fact that California's grid is becoming cleaner (emitting less carbon) each year, which inherently reduces the carbon footprint of the campus.

There are a range of all-electric heating technologies that work well for new construction projects. However, converting the existing natural gas heating systems to all-electric has historically been challenging from a technological and financial standpoint. Air-source heat pump (ASHP) technology which use traditional refrigerants have limitations on the temperatures they can produce (typically a maximum supply temperature of approximately 130F), which may make them incompatible with typical legacy heating systems which utilize 160-180F temperatures. The renovations required to make existing buildings compatible with ASHP technology can be prohibitively expensive. These renovations may require replacement of some heating coils to accommodate lower water temperature, and often piping/coupling systems need to also be replaced. Furthermore, ASHP technology is limited to a lower ambient temperature of ~25F, which means that supplemental heating may be required on the coldest days of the year.

Water-source heat pumps (WSHP) are more flexible, with supply temperatures as high as 170F. These require a water-based heat source/sink, such as a ground loop via a geo-exchange system. Geo-exchange systems are often very costly due to the cost of drilling vertical wells or excavating for horizontal systems. These costs and space constraints typically preclude water-source heat pumps as a retrofit solution.

Transcritical heat pump (TCHP) technology is relatively new to building comfort heating and cooling which is addressing the traditional challenges of ASHPs and WSHPs. This technology utilizes CO₂ as its refrigerant (known as R744), which enables hot water delivery temperatures of 180F at outdoor ambient conditions down to -15F. This allows "direct replacement" of natural gas boilers and domestic hot water heaters. This technology is still "emerging", with a limited number of installations in the U.S., however, it is expected that this technology will develop rapidly over the next 5 years.

For existing buildings with traditional boiler-based hydronic systems, an assessment process is recommended to determine what modifications are required in order to electrify these systems with the highest possible efficiency. The primary goal of this assessment is to determine if the existing hydronic systems is capable of operating at lower heating hot water temperatures while still maintaining design temperatures. Lowering the hot water temperatures allows for compatibility with a wider range of heat pump technology, and also allows them to operate much more efficiently. The following bullet points outline the assessment process:

- Review heating coils configuration - heating coil performance will be reduced when operating at lower hot water temperatures, however, in some cases, this performance derating can be overcome with modification to control sequences. In most cases, two-row heating coils at air handling units and VAV boxes can be utilized when lowering hot water temperatures from 180F to 140F, or even lower. The peak capacity of the coils is reduced with lower water temperatures, but simply increasing the warm-up time of the building may overcome these limitations. Also, reducing the temperature setback of the space will reduce the load that the coils must meet. Single-row coils will likely struggle to meet the load with reduced water temperatures and may need to be replaced.
- Conduct a hot water reset investigation – During the winter months, reduce the heating hot water temperature in 5-degree increments for one to two weeks at a time. This process will reveal which zones/coils are able to meet space loads with reduced water temperatures. As zones are discovered to be out of setpoint, increase the warm-up period or limit the temperature setback. Continue to reduce water temperatures and increase warmup period to determine if a lower water temperature will allow the building to maintain functionality. This process may reveal that certain zones/coils will function adequately, while others may need to be upgraded. The desired outcome of the reset investigation is a custom outdoor air reset control sequence that reduces hot water temperatures to a minimum, as a function of outside air temperature. For example, the goal may be to operate at 140F supply/ 100F return as often as possible but allows for increases up to 180F supply / 140F return on the coldest days of the year.

HVAC Electrification Strategy

Transcritical Heat Pumps

While this heat pump technology has long been used in commercial refrigeration for 20 years or more, it is more recently being applied to building HVAC and domestic hot water. Typically, these machines use CO₂, or R-744, as its refrigerant, which has a global warming potential (GWP) of 1, which is far below traditional refrigerants like R-410a (GWP of 2088) or R-134a (GWP of 1430). Furthermore, R-744 is able to operate with much higher temperatures, at or above 180F. However, like traditional heat pumps, transcritical heat pumps operate much more efficiently with lower supply water temperatures.

As the technology continues to advance, it may become a critical component of electrifying existing buildings that utilize hydronic heating. The graph on the right shows the efficiency curves for various operating conditions for Flow Environmental System’s model H transcritical heat pump. These trends show that while operating at “traditional” boiler system temperatures of 180F supply / 140F return, a COP of 1.75 is achieved. However, lowering the supply temperature to 140F dramatically improves efficiency, approaching a COP of 3.5. This highlights the importance of the hot water reset assessment process outline on the previous page.


Transcritical heat pump technology is also well suited for domestic hot water applications, where storage temperatures typically range from 125F – 140F. Systems like Sanden and Lync are able to achieve COPs above 5, which allows for significant improvements to operation cost and carbon emissions associated with domestic hot water.

The links below are examples of transcritical heat pump technology that are recommended for investigation by future design teams for use in both new construction and retrofit projects.

<https://www.flowenvirosys.com/products>

<https://www.smallplanetsupply.com/sanc02>

<https://www.lyncbywatts.com/>



HVAC Electrification Strategy

Central Plant Opportunities


An all-electric central utility plant (CUP) may be an effective strategy to employ as part of the early FMP projects. At Los Medanos College, the newly planned Health Sciences building is one of the first major projects that will occur within the core of the campus. It is in relatively close proximity to several other newly planned or renovated building. A central plant can be designed and planned at the new Health Sciences building with the intent to expand over time, as new buildings are built, and existing buildings are retrofitted.

For Contra Costa College, a central plant may be feasible as part of the renovation of Student Services or General Education buildings. However, space constraints may make this challenging.

For Diablo Valley College, a central plant may be feasible as part of the new academic complex, which is planned for construction in 2030. this central plant could then be available to serve the renovation projects as they occur in the later 2030's.

Utilizing a central plant, as opposed to each building having standalone heating and cooling equipment, offers many benefits in terms of efficiency, redundancy, and heat recovery. Centralizing the load of multiple buildings offers diversity in the load profile, which may allow for energy to be recovered (using heat recovery heat pumps) when simultaneous heating and cooling loads are required across a campus. Central plant equipment can be designed with proper modularity to allow for very efficient part load operation, as well as inherent redundancy. Thermal storage systems can be readily added to a central plant, allowing primary heating and cooling equipment to be dramatically downsized, as well as offering the ability to load shift to times when energy is cheap or when the grid is the cleanest (depending on District priority).

The downsides of a central plant approach are primarily cost and complexity. A significant infrastructure investment is required to install the initial phases of a central plant, sizing piping and electrical systems for their anticipated future loads. However, future buildings that connect to the central plant will be lower cost. The equipment is typically of a larger scale, often requiring specialized contractors to perform major maintenance. A relatively large area is often required to house the central plant equipment, which can be challenging for some campuses.



HVAC Electrification Strategy

Contra Costa College



HVAC Electrification Strategy

Contra Costa College – FMP Projects Pt.1

The 2024 Facilities Master Plan identifies 11 projects that will enhance the usability of the campus. These projects include new construction of 2 new buildings.

As part of the 4CD sustainability goals, each of these new buildings will be all-electric and LEED gold certified. The predicted EUI of these buildings is shown in the table below, along with the assumptions of building size and what year the projects will be built.

| New Construction Projects | | | | | |
|------------------------------------|------------|----------------------|----------------------------|--------------------------------------|--|
| Building | Area (ft2) | Year of Construction | Predicted EUI (kBtu/sf-yr) | Annual Electricity Consumption (kWH) | Notes |
| NEW MAINTENANCE AND OPERATIONS | 15,000 | 2035 | 20 | 87,921 | Coincides with demolition of Maintenance Shop and other low energy buildings |
| NEW STUDENT AND COMMUNITY BUILDING | 30,000 | 2033 | 25 | 219,803 | Coincides with demolition of Music and Art Buildings |

HVAC Electrification Strategy

Contra Costa College – FMP Projects Pt.2

The 2024 Facilities Master Plan identifies 11 projects that will enhance the usability of the campus. These projects include 9 renovations, 6 of which occur in the timeline of the energy study,

Renovation projects are anticipated to eliminate natural gas from the HVAC and plumbing systems, resulting in a substantial energy and carbon emissions reduction. These savings are summarized in the table below.

| Renovation Projects | | | | | | | |
|------------------------|------------|--------------------|--------------|----------------------------|------------------------------|----------------------------|---|
| Building | Area (ft2) | Year of Renovation | Existing EUI | Predicted EUI (kBtu/sf-yr) | Natural Gas Reduction (kBtu) | Electricity Reducton (kWh) | Notes |
| LIBRARY | 32,904 | 2031 | 54.0 | 23.1 | 1,045,915 | -8,606 | Electrification and LED as part of FMP Renovation |
| APPLIED ARTS & ADM. | 50,000 | 2030 | 52.4 | 33.5 | 1,063,650 | -34,692 | Electrification and second half of LEDs as part of FMP renovation, if lighting not done before |
| STUDENT SERVICES | 19,280 | 2027 | 68.3 | 32.1 | 763,183 | -19,483 | LED and electrification as part of FMP Refresh Renovation, full renovation is too far out to save this stuff and meet energy goals (2040). Boiler has 14 years left of RUL. |
| GENERAL EDUCATION BLDG | 51,234 | 2029 | 69.0 | 35.4 | 1,841,247 | -35,661 | Represents electrificationa and LED retrofit as part of FMP renovation |
| POOL | NA | 2026 | NA | NA | 2,460,335 | NA | Electrification of pool coinciding with FMP renovation of pool and timed with electrification of gym annex since they use the same boiler |
| GYM ANNEX* | 36,327 | 2026 | 44.2 | 23.4 | 1,170,611 | -122,526 | Electrification before end of equipment life to also electrify the boiler |

Renovations of the following buildings occur after and outside our energy plan:

- Performing Arts Center
- Child Development Center
- Full Student Services Renovation

*The gym annex shares a boiler with the pool and it is recommended to electrify this boiler at the pool renovation year, but no FMP work is planned for the Gym Annex building itself.

HVAC Electrification Strategy

Contra Costa College – Additional Efficiency Projects

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|--|------------|--------------|----------------------------|----------------------------|--------------------------|--|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| GYMNASIUM | 22,551 | 2034 | | | x (Furnace) | Furnace Heating- RTUs have 16-18 years of RUL, other single zone equipment has RUL of 11-16 years. | | | \$875,525 | \$875,525 | -63,532 | 606,985 | 46.1 | 28.7 |
| LOCKER ROOM BUILDING | 8,732 | 2034 | | | x (Boiler) | Boiler 11 Years, recommend electric heat pump swap | | | \$406,816 | \$406,816 | -50,720 | 484,578 | 73.9 | 38.2 |
| VOC ARTS/COMPUTER TECH | 30,912 | 2025 | x | | x (Furnace) | RTU at 1 | \$323,030 | | \$807,576 | \$1,130,606 | -38,380 | 1,272,035 | 78.8 | 41.9 |
| ATHLETIC TRAINING AND KINESIOLOGY CENTER | 4,531 | 2034 | | | x (Furnace) | RTU at 18 | | | \$175,913 | \$175,913 | -18,958 | 181,122 | 53.9 | 28.2 |
| MAINT/POLICE OFFICES | 6,570 | 2025 | x | | x (Furnace) | RTU at 0 (EOL) | \$68,657 | | \$171,641 | \$240,298 | -16,287 | 348,032 | 88.1 | 43.6 |
| STUDENT & ADMINISTRATION | 53,577 | 2034 | x | | x (Boiler) | boilers and ahus at 12 years, boiler type upgrade | \$832,034 | | \$2,496,103 | \$3,328,138 | -40,138 | 1,952,641 | 71.9 | 38.1 |
| PERFORMING ARTS CENT | 21,000 | 2027 | | | x (Boiler) | 19 years (out of 30) of remaining useful life for boilers | | | \$718,935 | \$718,935 | -111,569 | 1,065,926 | 68.1 | 35.5 |

*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.


HVAC Electrification Strategy

Contra Costa College – District Energy Project Savings and Cost Summary

| District Energy Projects Cumulative Cost | | | | District Energy Project Annual Cost Savings (2023 CCC Utility Rates) | | | | |
|--|----------|-----------------|-------------|--|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting | Controls | Electrification | Total | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| \$1,223,721 | \$0 | \$5,652,509 | \$6,876,230 | \$ 66,994 | \$ - | \$ 122,364 | -\$148,495 | \$40,864 |

| District Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | | District Energy Project Annual Cost Savings (2035 Estimated CCC Utility Rates) | | | | |
|---|--------------------------|----------------------------|----------------------------|--|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| 952,477 | 0 | 3,800,134 | 5,911,320 | \$ 119,636 | \$ - | \$ 218,514 | -\$265,177 | \$72,974 |


Non-FMP Project Costs (Dollars)



HVAC Electrification Strategy

Contra Costa College – District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. In this graph electrification provides a much larger source of emissions reduction than PV for the CCC campus. This is due to the PV being associated with the lower emitting MCE account/grid for the campus. The advantage of the PV being associated with MCE energy is that it has a large effect on the annual utility costs of the campus. Electrification is also very important for meeting the campus building EUI targets.



Energy Timeline




HVAC Electrification Strategy

Contra Costa College – Campus EUI Trend

Overall, electrification is very important to achieving campus EUI and emissions goals, as large reductions in gas kBTU results in much smaller increases in electric kBTU. This campus presents an opportunity to reduce EUIs below the district 2030 and 2035 targets in order to reduce the district wide average to meet the target. The electrification that results in these high EUI reductions is also important for this campuses emissions reduction, since the PV has a relatively low carbon impact.


Campus EUI (kBTU/sf-yr) by Type (Excluding Renewables)



HVAC Electrification Strategy

Contra Costa College – Campus Utility Costs Trend

The chart below shows the total and fuel specific utility costs for the campus going forwards. This is based on an assumption of a 4% escalation of electricity and gas costs per year, as well as the campus being in a net metering scheme which allows for the PV kWh to have the same value as electric consumption kWh. The 2022 use with escalated electricity and gas costs are also shown with a dotted line, to show the impact of the cumulative interventions performed on the campus. Renewables and efficiency upgrades like controls and LEDs reduce the operating cost of the campus. The renewables being associated with the more expensive MCE electricity allow for a higher campus cost reduction, with a tradeoff of less CO2 offset compared to potential PV associated with constellation. The 2.167 MW of additional future PV required to offset electricity consumption for the campus in 2035 would result in an estimated additional around \$1,521,202 a year of cost savings with 2035 utility rates (Assuming the future PV is associated with MCE).




Planned PV is assumed to be installed in the year prior to the start of 2026.

HVAC Electrification Strategy

Contra Costa College – Campus Emissions Trend

The graph below shows the emissions trend accounting FMP and non-FMP projects. Emissions offset by renewables deprecate over time due to decreasing grid emissions. Emissions from electrical consumption deprecate at the same rate. The starting emissions are based on weather normalized data. Due to the PV being associated with the low emission MCE electricity, very large amounts of additional PV would be needed to offset the remaining emissions. If future PV was associated with MCE, and the MCE and constellation grids become cleaner at a similar rate, 13.6 MW of additional PV capacity would need to be installed to offset all emissions by 2035. If the PV was associated with constellation, this would go down to less than 1 MW. The rate of emissions for Constellation and MCE is likely to change over time, and the relative difference in emissions between the two providers is likely to change. It is recommended to consider these emissions rates for future PV installation. Otherwise, to meet the goal, offsets would need to be purchased until the California grid is legislated to be emissions free by 2045. This amount would start at about 252 tons per year in 2035 and decrease to 135 tons per year by 2040 as the grid approaches the legislative targets. If the CA grid/Constellation emissions rate approaches zero carbon faster or slower than legislatively required, the offsets required could go up or down. A good efficiency and emissions reduction strategy may not require each individual campus to meet the sustainability goals, but rather the ensemble of campuses meeting the goals. This will allow for taking advantage of deploying PV where it is most effective (campuses associated with higher emitting utilities) or where there is the most capacity, and purchasing offsets or clean energy at a district level for the net emissions that remain.



3.

Diablo Valley College/
San Ramon Center

Carbon and Energy Benchmarking



Building Benchmarking Study - Introduction


As part of the District Sustainability and Electrification plan, the portfolio of campus buildings has been subject to a benchmarking study to attempt to determine the highest priority target buildings for electrification and chart a path for the district towards meeting its sustainability goals. The data used for this benchmarking study consists of engineering and architectural drawings provided by the community college district, campus wide electricity and gas usage data, and results from a building equipment and facilities audit performed by Bureau Veritas. Building EUIs were also adjusted based on known operational configurations for particular campuses and buildings, as well as the mechanical and air systems.

Electricity and gas usage was estimated for each individual building on the campus based on available benchmarking data by building type for the bay area climate zones, the state of California as a whole, and available campus wide billing data. These estimates were then adjusted based on known building specific characteristics. Large multi-purpose campus buildings were divided into the various use-types they are composed of in order to provide an accurate EUI estimate for the building, as well as a use-type specific EUI for that campus.

The estimates were then revised based on a dialogue with the district on the values, particular building meter data, multi-building line meter data, and site electricity data that was made available.

The energy and carbon impact of the pools were estimated based on available boiler data for the Contra Costa College pool and then a gas usage per square foot per year was applied to the Diablo Valley College pool in order to estimate the portion of the gas usage that is not part of a building EUI.

Building type energy data from the bay area, California, and the United States came from the [Lawrence Berkley National Laboratory Building Performance Database](#) and was adjusted or compiled into campus use types based on engineering judgement.




Sample BPD Query

The Energy Star [Commercial Buildings Energy Consumption Survey](#) and data from the [Higher Education Benchmarking Initiative](#) were also used to estimate end-use breakdowns and as a comparison point for realistic data for particular types of campuses.




Sample CBECs Data

DVC 2022 Weather Normalized DVC Campus EUI
(kBTU/sf) (Pool not active in 2022)



■ Elec EUI ■ Building Gas EUI ■ Site Elec EUI

DVC 2022 Weather Normalized DVC Campus Emissions
(Pool not active in 2022)




■ Total Building Elec Emissions ■ Total Building Gas Emissions
■ Total Site Elec Emissions

DVC

Campus-Level Benchmarking

The campus EUI graph sums the total gas and electricity associated with the campus and divides them by the square footage of campus buildings included in the EUI study. The breakdown is representative of the split between gas and electricity use on the campus. The campus emissions chart shows the portion of the campuses total emissions that are associated with each fuel type. This data is all based on weather normalized data for the gas and electricity use and does not exactly match the real quantities but is better for a forward-looking analysis of the campus energy. DVC electricity use is associated with a Constellation energy which as a grid emissions rate of 701 lbs CO2e per MWH of electricity. The high emissions rate for the grid here means that a majority of the emissions for the campus come from electricity use. The area for EUI calculations in 2022 was 746,198 ft². The pool did not operate in 2022 but its energy was including in following years for the campus.




DVC

Campus Program Breakdown

The campus area breakdown shows the portion of the campus square footage associated with each of the program type categories in our study. Buildings with multiple use types have had their square footage distributed proportionally.

Program EUI - DVC (kBtu/sf)




DVC

EUI per Program Type

The program EUIs are based on the weighted average of individual EUIs of buildings in each program classification, which may vary. These programs were assigned for energy analysis purposes and may not match other campus program breakdowns.

DVC Building EUI Breakdown (kbtu/sf-yr)*




DVC

Energy Breakdown
by Building

*Some buildings with negligible energy use are excluded from this graph

Total Carbon Emissions (Kg C02e)



DVC

Total Emissions

DVC Benchmark Data Summary Table (Part 1)

| Building | Age | Area | EUI | Gas EUI | Electric EUI | Total kBTU | Gas kBTU | Elec kBTU | Gas Carbon Emissions (metric tons CO2) | Electricity Carbon Emissions (metric tons CO2) | Total Carbon Emissions (metric tons CO2) |
|----------------------------------|------|--------|-------|---------|--------------|------------|-----------|-----------|--|--|--|
| PHYSICAL SCIENCE | 2000 | 41,220 | 125.0 | 46.9 | 78.2 | 5,154,479 | 1,931,487 | 3,222,992 | 103 | 301 | 403 |
| ENGINEERING TECHNOLOGY | 1971 | 36,551 | 136.8 | 86.4 | 50.4 | 5,000,708 | 3,157,794 | 1,842,914 | 168 | 172 | 340 |
| LIFE SCIENCES | 1960 | 33,844 | 127.4 | 48.7 | 78.7 | 4,311,049 | 1,646,849 | 2,664,200 | 87 | 249 | 336 |
| LIBRARY | 1970 | 63,201 | 60.4 | 26.2 | 34.2 | 3,819,552 | 1,655,945 | 2,163,607 | 88 | 202 | 290 |
| HOSPITALITY STUDIES & FOOD COURT | 2014 | 44,779 | 64.0 | 28.0 | 36.0 | 2,866,894 | 1,253,717 | 1,613,177 | 67 | 151 | 217 |
| STUDENT SERVICES | 2013 | 41,103 | 63.8 | 25.4 | 38.4 | 2,621,456 | 1,044,184 | 1,577,272 | 55 | 147 | 203 |
| ART COMPLEX | 2022 | 45,600 | 41.3 | 0.0 | 41.3 | 1,883,280 | 0 | 1,883,280 | 0 | 176 | 176 |
| LIBERAL ARTS | 1972 | 25,246 | 86.9 | 36.2 | 50.7 | 2,194,887 | 914,006 | 1,280,881 | 49 | 120 | 168 |
| BUSINESS & WORLD LANGUAGE | 2002 | 26,676 | 68.8 | 24.4 | 44.4 | 1,836,435 | 651,396 | 1,185,039 | 35 | 111 | 145 |
| HUMANITIES | 1964 | 16,428 | 105.4 | 40.1 | 65.4 | 1,732,300 | 658,536 | 1,073,764 | 35 | 100 | 135 |
| FACULTY OFFICE | 1972 | 22,316 | 63.0 | 0.0 | 63.0 | 1,405,908 | 0 | 1,405,908 | 0 | 131 | 131 |
| ADMINISTRATION BLDG | 1973 | 19,437 | 78.2 | 31.2 | 47.0 | 1,520,586 | 607,315 | 913,271 | 32 | 85 | 118 |
| LEARNING CENTER | 1974 | 15,914 | 86.9 | 34.8 | 52.1 | 1,383,563 | 553,871 | 829,692 | 29 | 77 | 107 |
| MATH BUILDING | 1998 | 24,211 | 55.8 | 26.7 | 29.1 | 1,351,410 | 645,945 | 705,465 | 34 | 66 | 100 |
| PERFORMING ARTS | 1978 | 34,423 | 42.7 | 28.1 | 14.7 | 1,470,840 | 965,573 | 505,267 | 51 | 47 | 98 |
| SCIENCE & TECHNOLOGY | 1960 | 19,505 | 66.5 | 33.5 | 32.9 | 1,296,107 | 653,422 | 642,685 | 35 | 60 | 95 |
| FITNESS & EXERCISE | 1967 | 24,274 | 35.8 | 0.0 | 35.8 | 867,796 | 0 | 867,796 | 0 | 81 | 81 |
| DVC FIELDHOUSE | 2021 | 18,178 | 44.0 | 0.0 | 44.0 | 799,832 | 0 | 799,832 | 0 | 75 | 75 |
| STUDENT UNION | 1997 | 12,744 | 76.4 | 41.1 | 35.2 | 973,081 | 524,186 | 448,895 | 28 | 42 | 70 |
| MUSIC | 1963 | 14,522 | 65.1 | 34.3 | 30.8 | 945,382 | 498,308 | 447,074 | 26 | 42 | 68 |
| GYMNASIUM | 1955 | 18,092 | 35.8 | 0.0 | 35.8 | 646,789 | 0 | 646,789 | 0 | 60 | 60 |
| BOOKSTORE | 2006 | 13,462 | 53.9 | 26.5 | 27.4 | 725,602 | 356,205 | 369,397 | 19 | 34 | 53 |


The pool uses 2,143,000 kBTU per year, or about 177 kBTU/sf/yr.

DVC Benchmark Data Summary Table (Part 2)

| Building | Age | Area | EUI | Gas EUI | Electric EUI | Total kBTU | Gas kBTU | Electric kBTU | Gas Carbon Emissions (metric tons CO2) | Electricity Carbon Emissions (metric tons CO2) | Total Carbon Emissions (metric tons CO2) |
|--|------|--------|------|---------|--------------|------------|----------|---------------|---|---|---|
| PUMA CENTER | 1972 | 7,375 | 78.5 | 32.9 | 45.6 | 579,202 | 242,562 | 336,639 | 13 | 31 | 44 |
| PLANETARIUM | 1960 | 7,481 | 69.0 | 29.4 | 39.6 | 516,277 | 219,660 | 296,617 | 12 | 28 | 39 |
| WAREHOUSE/MAINTENCE | 1980 | 25,900 | 12.8 | 0.0 | 12.8 | 330,225 | 0 | 330,225 | 0 | 31 | 31 |
| EARLY CHILDHOOD EDUCATION NORTH | 1980 | 4,639 | 78.5 | 34.1 | 44.4 | 364,328 | 158,421 | 205,907 | 8 | 19 | 28 |
| AQUATICS | 2023 | 6,700 | 35.8 | 0.0 | 35.8 | 239,525 | 0 | 239,525 | 0 | 22 | 22 |
| EARLY CHILDHOOD EDUCATION SOUTH | 1972 | 3,792 | 69.0 | 37.5 | 31.4 | 261,553 | 142,377 | 119,176 | 8 | 11 | 19 |
| SCIENCE CENTER 2 | 1976 | 4,184 | 44.7 | 0.0 | 44.7 | 187,150 | 0 | 187,150 | 0 | 17 | 17 |
| HFO FACULTY OFFICES | 2021 | 4,570 | 37.8 | 0.0 | 37.8 | 172,746 | 0 | 172,746 | 0 | 16 | 16 |
| POLICE & SAFETY SERVICES | 2009 | 2,880 | 44.7 | 0.0 | 44.7 | 128,822 | 0 | 128,822 | 0 | 12 | 12 |
| OFFICE ANNEX - WLC | 1991 | 2,006 | 49.1 | 0.0 | 49.1 | 98,575 | 0 | 98,575 | 0 | 9 | 9 |
| SCIENCE CENTER 5 | 1976 | 1,597 | 63.5 | 33.0 | 30.5 | 101,416 | 52,631 | 48,785 | 3 | 5 | 7 |
| COMMUNITY SERVICE CENTER | 2002 | 1,569 | 63.5 | 35.6 | 27.9 | 99,650 | 55,864 | 43,785 | 3 | 4 | 7 |
| SCIENCE CENTER 3 | 1976 | 1,281 | 49.7 | 0.0 | 49.7 | 63,666 | 0 | 63,666 | 0 | 6 | 6 |
| HORTICULTURE GREENHOUSE 1-2 | 1975 | 4,409 | 10.8 | 0.3 | 10.5 | 47,397 | 1,102 | 46,295 | 0 | 4 | 4 |
| SCIENCE CENTER 4 | 1976 | 846 | 63.5 | 33.0 | 30.5 | 53,724 | 27,881 | 25,844 | 1 | 2 | 4 |
| KINESIOLOGY MODULAR POLICE-ET STORAGE BUILDING | 2007 | 956 | 39.1 | 0.0 | 39.1 | 37,332 | 0 | 37,332 | 0 | 3 | 3 |
| TEMP 14 ORNAMENTAL HORT | 1966 | 2,200 | 12.8 | 0.0 | 12.8 | 25,500 | 0 | 25,500 | 0 | 2 | 2 |
| FOOTBALL OFFICE | 1965 | 2,000 | 12.5 | 4.5 | 8.0 | 27,442 | 9,834 | 17,608 | 1 | 2 | 2 |
| SCIENCE CENTER 6 | 2002 | 451 | 44.7 | 0.0 | 44.7 | 20,173 | 0 | 20,173 | 0 | 2 | 2 |
| SCIENCE CENTER 7 | 1976 | 330 | 49.7 | 0.0 | 49.7 | 16,401 | 0 | 16,401 | 0 | 2 | 2 |
| SCIENCE CENTER 8 | 1976 | 389 | 21.3 | 0.0 | 21.3 | 8,286 | 0 | 8,286 | 0 | 1 | 1 |
| SCIENCE CENTER 8 | 1976 | 260 | 21.3 | 0.0 | 21.3 | 5,538 | 0 | 5,538 | 0 | 1 | 1 |

The pool uses 2,143,000 kBTU per year, or about 177 kBTU/sf/yr.


Energy Use Intensity (EUI) - PHC



SRC




2022 Weather Normalized SRC Campus EUI (kBtu/sf)



■ SRC Building Elec EUI ■ SRC Building Gas EUI ■ SRC Site Elec EUI

2022 Weather Normalized SRC Campus Emissions



■ Total Elec Emissions ■ Total Gas Emissions

San Ramon Center Campus-Level Benchmarking

The San Ramon facility is associated with Constellation and as an emissions rate of 701 lbs CO2e per MWH of electricity. The facility is 88,500 sf.

San Ramon Center Building Benchmark Data Summary

| Building | Age | Area | EUI | Gas EUI | Total kBTU | Gas kBTU | Elec KBTU | Gas Carbon Emissions (kg CO2) | Electricity Carbon Emissions | Total Carbon Emissions (Kg CO2e) |
|--------------------------|------|--------|------|---------|------------|-----------|-----------|-------------------------------|------------------------------|----------------------------------|
| SAN RAMON MAIN BUILDING* | 2006 | 76,528 | 83.5 | 34.3 | 49.2 | 6,389,418 | 2,621,282 | 3,768,136 | 306,218 | 773,942 |
| SAN RAMON LIBRARY* | 2021 | 8,842 | 55.5 | 28.1 | 27.3 | 490,399 | 248,582 | 241,818 | 29,039 | 49,667 |

*Energy from the SRC mechanical plant facility is associated with the buildings that it serves, while its area is still included in SRC campus wide EUI calculations.

Electric Infrastructure Assessment



Electrical Infrastructure Assessment - Introduction

As part of the Electrification Plan, Interface Engineering evaluated the available electrical system capacity at each campus to accommodate the future electrical demands from electrification, renewable energy deployment, and EV charging. The goal of this assessment is to confirm the capacity at the main campus feeders and switchgear. Downstream equipment, such as panels, wiring, and transformers, are not included in this assessment.

We have assessed the available electrical capacity at each of the District's campuses, as well as the District Offices and Brentwood Building. The available capacity has been evaluated using PG&E utility data (15-minute interval data) and PV inverter output data (hourly data provided from the district) for the period of May 2022 through August 2023.


For electrical services that include PV production, the generation data from net generation output (NGOM) meters and/or direct inverter output data is added to the consumption data reported at the main revenue meter, establishing the true demand on the service.

The demand (kW) reported for each service is a calculated value, using the consumption and PV production data (kWh). For example, if 100 kWh are consumed in a 15-min timestep, then the calculated demand for that timestep would be reported as 400 kW (100 kWh X (1/4 hours)).


Diablo Valley College

- DVC campus is powered by an existing 1200A, 4.16kV service with a total capacity of 8646.4 kW. The measured maximum demand on this service was 2733.6 kW.
- DVC data appears complete.
- Demand values include PV system generation data and service consumption data.
- An outlier datapoint of 4043.9 KW is ignored.
- Top 0.1% of demand used for maximum service demand.
- The existing service has an available capacity of 60.5%, or 5229.4kW.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|----------------|
| 1 | Top 0.1% of Demand | 2733.6 kW |
| 2 | Maximum Demand | 4043.9 kW |
| 3 | Maximum Demand Occurrence | 6/4/2023 15:00 |
| 4 | Service Voltage | 4.16 kV |
| 5 | Service Amperage | 1200 A |
| 6 | Service Capacity | 8646.4 kW |
| 7 | Maximum Demand [2] | 2733.6 kW |
| 8 | Maximum Demand * 125% | 3417.0 kW |
| 9 | Available Capacity [6-8] | 5229.4 kW |
| 10 | Percent Available Capacity [9/6] | 60.5% |




Diablo Valley College Single Line Diagram




San Ramon College

- SRC campus is powered by an existing 2000A, 480V service with a total capacity of 1662.8kW. The maximum demand on this service was 304.0kW.
- SRC data appears complete.
- The existing service has an available capacity of 77.1%, or 1282.8kW.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|-----------------|
| 1 | Top 0.1% of Demand | 272.0 kW |
| 2 | Maximum Demand | 304.0 kW |
| 3 | Maximum Demand Occurrence | 3/13/2023 13:00 |
| 4 | Service Voltage | 480 V |
| 5 | Service Amperage | 2000 A |
| 6 | Service Capacity | 1662.8 kW |
| 7 | Maximum Demand [2] | 304.0 kW |
| 8 | Maximum Demand * 125% | 380.0 kW |
| 9 | Available Capacity [6-8] | 1282.8 kW |
| 10 | Percent Available Capacity [9/6] | 77.1% |



San Ramon College Single Line Diagram



Renewable Energy Deployment



Renewable Energy Deployment Strategy

Introduction

On-site renewable energy generation is a critical component of 4CD’s sustainability plan to achieve net zero carbon emissions by 2035. The district currently has approximately 3.2 MW of photovoltaic (PV) solar panel systems across CCC, DVC, and LMC, which produce nearly 3.8 MWh annually. This represents approximately 19% of the district’s electricity consumption.

As part of its plan to increase on-site renewable production, 4CD has five additional PV projects approved by PG&E for installation but have yet to be funded. For the purposes of estimating the impact of these approved projects, it is assumed that these systems will be installed in 2026. An estimate of the total development costs are shown in the table below, which based on the information provided by Sage Renewables. These costs are based on recent quote that 4CD received for the Brentwood system, which indicated a total cost of \$7.87/watt for carport arrays. The Brentwood, DVC, and LMC installations are also planned to include battery energy storage systems (BESS), which will further enhance the cost reduction capabilities of these systems.

The tables to the right summarize the existing and planned PV systems, including their DC capacity, orientation and expected annual production rate (which vary slightly by campus and by array orientation). The table at the bottom indicates the % of electrical consumption that is met with the existing and future PV systems.

The campus site plans on the subsequent slides indicate the existing and planned PV locations on each campus, including the context of the newly planned buildings as part of the FMP. The site plans also indicate areas that may potentially be used for additional PV in the future.

The energy and carbon impact of the existing and planned arrays are discussed in more detail in the “District Energy and Carbon Timeline” chapter of this report.

The table below shows the future PV, beyond what is currently planned, that would be required in order to achieve net zero emissions for the specific campuses in 2035, and the associated cost of deployment in 2024 PV costs.

| Future PV Summary (Scenario A) | | | | | |
|--------------------------------|-----------|--------------|---------------------------------|--|--------------------------------|
| Campus | Size (kW) | Cost* | Est. Annual Production (kWh/yr) | Predicted Electrical Consumption in 2035 | % Future Load Met by Future PV |
| DVC | 3,844 | \$30,252,280 | 5,766,000 | 8,782,110 | 66% |
| CCC | 2,167** | \$17,054,290 | 3,250,500 | 5,143,509 | 63% |
| LMC | 591 | \$4,651,170 | 886,500 | 4,276,119 | 21% |
| SRC | 433 | \$3,407,710 | 649,500 | 1,413,618 | 46% |
| DO | 468*** | \$3,683,160 | 702,000 | 701,838 | 100% |
| BEC | 166 | \$1,306,420 | 249,000 | 749,521 | 33% |

*costs are based on estimates for PV projects for the district in 2024
**based on offsetting kWh instead of carbon emissions, due to the utility split for CCC between MCE and Constellation
***Due to limited space at this facility, this PV could be installed on another Constellation Campus like DVC, LMC, or SRC to have the same effect.

| Existing PV systems | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | Kwh/KW* | Annual Energy Production (kWh) |
| Contra Costa College - Lot 9 | 403 | 225 | 1053 | 424,359 |
| Diablo Valley College - Lot 1 | 567 | 270 | 1297 | 735,289 |
| Diablo Valley College - Lot 3 | 267 | 270 | 1297 | 346,247 |
| Diablo Valley College - Lot 4 | 548 | 270 | 1297 | 710,650 |
| Los Medanos College - Lot B | 763 | 150 | 1139 | 868,904 |
| Los Medanos College - Lot C | 638 | 230 | 1128 | 719,953 |
| Total | 3,186 | | | 3,805,402 |

*The existing PV production rates are 20-30% below the expected rate, based on the location and orientation of the systems. This may indicate performance issues with the panels and inverters.

| Planned PV systems | | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | kWh/K W | Annual Energy Production (kWh) | Project Development Costs (\$) |
| Diablo Valley College - Lot 5 | 878 | 270 | 1564 | 1,373,000 | \$6,909,860 |
| Contra Costa College - Lot 1 | 947 | 225 | 1551 | 1,469,000 | \$7,452,890 |
| Los Medanos College | 1,154 | 150 | 1560 | 1,800,000 | \$9,081,980 |
| San Ramon Center - Main Lot | 483 | 225 | 1580 | 763,000 | \$3,801,210 |
| Brentwood Center - Main Lot | 322 | 180 | 1556 | 501,032 | \$2,534,140 |
| Total | 3,784 | | | 5,906,032 | \$29,780,080 |


| Renewable Energy Summary | | | | |
|--------------------------|---------------------------------------|----------------------|---------------------|---------------------------|
| | Annual Electricity Consumption (kWh)* | % Met by Existing PV | % Met by Planned PV | Total Planned Renewable % |
| CCC | 4,414,407 | 10% | 33% | 43% |
| DVC | 8,618,555 | 21% | 16% | 37% |
| LMC | 4,783,853 | 33% | 38% | 71% |
| SRC | 1,200,248 | 0% | 64% | 64% |
| Brentwood | 573,479 | 0% | 87% | 87% |
| District Offices | 657,697 | 0% | 0% | 0% |
| District | 20,248,239 | 19% | 28% | 47% |

*True 2022 value that is not weather normalized

Diablo Valley College PV Systems

Planned System

- 878 KW @ parking lot 5
- Planned PV offsets ~ 16% of the campus's 2022 electricity




Existing System

- 1,382 KW @ parking lot 1/3/4
- Existing PV offsets ~ 21% of the campus's 2022 electricity

Potential Future System

- Potential PV offsets remaining based on electrical consumption and emissions in 2035 projections
- 3.84 MW required, approximately 192k ft² panel area, based on current PV technology (future location not determined at this time)

San Ramon Center PV Systems



Planned System

- 483 KW at main lot
- Planned PV offsets ~ 64% of the campus's 2022 electricity

Potential Future System

- 433KW
- Potential PV offsets remaining based on electrical consumption and emissions in 2035 projections
- Approximately 21.5k ft² panel area, based on current PV technology
- Location of future PV not determined at this time.

District Energy Projects



Electrification Plan Introduction

In 2022, more than 48% of the electricity delivered by California's grid was generated by renewable sources such as solar photovoltaics, wind, biomass, and hydroelectric. This percentage will increase over time, as state laws such as SB100 mandate that CA's grid achieve 100% carbon-free generation by 2045. This means that by electrifying legacy natural gas heating systems, the carbon footprint associated with these loads will trend towards zero. For the Contra Costa Community College district in 2022, ~45% of its electricity was provided by renewable resources (including grid-supplied and on-site generation).

The purpose of this study is to support the master-planning effort for the Contra Costa Community College District (4CD) with a district-wide electrification plan. The plan provides an analysis of how electrifying the district's natural gas heating systems and deploying renewable energy systems will reduce the district's energy consumption and carbon footprint.

The primary goal of the electrification plan is to assist the district in meeting its sustainability goals, as outlined in the "2022 4CD District Wide Energy & Sustainability Goals" document.

The electrification plan consists of the following components:

- Building Benchmarking Report
- Electrical Systems Assessment
- Campus Photovoltaic Deployment Assessment.
- Building Electrification Strategy
- District Energy and Carbon Timeline

4CD has adopted a set of sustainability goals which target significant reductions in carbon emissions across the entire organization by 2035. The electrification study addresses the greenhouse gas (GHG) and renewable energy goals by proposing and quantifying the impacts of building replacement and renovation projects, renewable energy systems, as well as additional efficiency projects such as LED lighting, building management controls, metering upgrades and HVAC electrification.

4CD's goals are focused on the two primary dates of 2030 and 2035. The 2030 goals include reducing GHG emissions by 75% below the 2013 baseline and reducing the district energy use intensity (EUI) by 25%. The 2035 goals include reducing GHG emissions by 100% and reducing district EUI by 40%.

HVAC Electrification Strategy

Contra Costa Community College District has adopted a broad set of sustainability goals and practices that will result in dramatic reductions in energy consumption and carbon emissions from its buildings. A key component of these goals is the requirement that all newly constructed buildings are all-electric (no fossil fuel combustion used for space heating). This approach leverages the fact that California's grid is becoming cleaner (emitting less carbon) each year, which inherently reduces the carbon footprint of the campus.

There are a range of all-electric heating technologies that work well for new construction projects. However, converting the existing natural gas heating systems to all-electric has historically been challenging from a technological and financial standpoint. Air-source heat pump (ASHP) technology which use traditional refrigerants have limitations on the temperatures they can produce (typically a maximum supply temperature of approximately 130F), which may make them incompatible with typical legacy heating systems which utilize 160-180F temperatures. The renovations required to make existing buildings compatible with ASHP technology can be prohibitively expensive. These renovations may require replacement of some heating coils to accommodate lower water temperature, and often piping/coupling systems need to also be replaced. Furthermore, ASHP technology is limited to a lower ambient temperature of ~25F, which means that supplemental heating may be required on the coldest days of the year.

Water-source heat pumps (WSHP) are more flexible, with supply temperatures as high as 170F. These require a water-based heat source/sink, such as a ground loop via a geo-exchange system. Geo-exchange systems are often very costly due to the cost of drilling vertical wells or excavating for horizontal systems. These costs and space constraints typically preclude water-source heat pumps as a retrofit solution.

Transcritical heat pump (TCHP) technology is relatively new to building comfort heating and cooling which is addressing the traditional challenges of ASHPs and WSHPs. This technology utilizes CO₂ as its refrigerant (known as R744), which enables hot water delivery temperatures of 180F at outdoor ambient conditions down to -15F. This allows "direct replacement" of natural gas boilers and domestic hot water heaters. This technology is still "emerging", with a limited number of installations in the U.S., however, it is expected that this technology will develop rapidly over the next 5 years.

For existing buildings with traditional boiler-based hydronic systems, an assessment process is recommended to determine what modifications are required in order to electrify these systems with the highest possible efficiency. The primary goal of this assessment is to determine if the existing hydronic systems is capable of operating at lower heating hot water temperatures while still maintaining design temperatures. Lowering the hot water temperatures allows for compatibility with a wider range of heat pump technology, and also allows them to operate much more efficiently. The following bullet points outline the assessment process:

- Review heating coils configuration - heating coil performance will be reduced when operating at lower hot water temperatures, however, in some cases, this performance derating can be overcome with modification to control sequences. In most cases, two-row heating coils at air handling units and VAV boxes can be utilized when lowering hot water temperatures from 180F to 140F, or even lower. The peak capacity of the coils is reduced with lower water temperatures, but simply increasing the warm-up time of the building may overcome these limitations. Also, reducing the temperature setback of the space will reduce the load that the coils must meet. Single-row coils will likely struggle to meet the load with reduced water temperatures and may need to be replaced.
- Conduct a hot water reset investigation – During the winter months, reduce the heating hot water temperature in 5-degree increments for one to two weeks at a time. This process will reveal which zones/coils are able to meet space loads with reduced water temperatures. As zones are discovered to be out of setpoint, increase the warm-up period or limit the temperature setback. Continue to reduce water temperatures and increase warmup period to determine if a lower water temperature will allow the building to maintain functionality. This process may reveal that certain zones/coils will function adequately, while others may need to be upgraded. The desired outcome of the reset investigation is a custom outdoor air reset control sequence that reduces hot water temperatures to a minimum, as a function of outside air temperature. For example, the goal may be to operate at 140F supply/ 100F return as often as possible but allows for increases up to 180F supply / 140F return on the coldest days of the year.

HVAC Electrification Strategy

Transcritical Heat Pumps

While this heat pump technology has long been used in commercial refrigeration for 20 years or more, it is more recently being applied to building HVAC and domestic hot water. Typically, these machines use CO₂, or R-744, as its refrigerant, which has a global warming potential (GWP) of 1, which is far below traditional refrigerants like R-410a (GWP of 2088) or R-134a (GWP of 1430). Furthermore, R-744 is able to operate with much higher temperatures, at or above 180F. However, like traditional heat pumps, transcritical heat pumps operate much more efficiently with lower supply water temperatures.

As the technology continues to advance, it may become a critical component of electrifying existing buildings that utilize hydronic heating. The graph on the right shows the efficiency curves for various operating conditions for Flow Environmental System’s model H transcritical heat pump. These trends show that while operating at “traditional” boiler system temperatures of 180F supply / 140F return, a COP of 1.75 is achieved. However, lowering the supply temperature to 140F dramatically improves efficiency, approaching a COP of 3.5. This highlights the importance of the hot water reset assessment process outline on the previous page.


Transcritical heat pump technology is also well suited for domestic hot water applications, where storage temperatures typically range from 125F – 140F. Systems like Sanden and Lync are able to achieve COPs above 5, which allows for significant improvements to operation cost and carbon emissions associated with domestic hot water.

The links below are examples of transcritical heat pump technology that are recommended for investigation by future design teams for use in both new construction and retrofit projects.

<https://www.flowenvirosys.com/products>

<https://www.smallplanetsupply.com/sanc02>

<https://www.lyncbywatts.com/>



HVAC Electrification Strategy

Central Plant Opportunities


An all-electric central utility plant (CUP) may be an effective strategy to employ as part of the early FMP projects. At Los Medanos College, the newly planned Health Sciences building is one of the first major projects that will occur within the core of the campus. It is in relatively close proximity to several other newly planned or renovated building. A central plant can be designed and planned at the new Health Sciences building with the intent to expand over time, as new buildings are built, and existing buildings are retrofitted.

For Contra Costa College, a central plant may be feasible as part of the renovation of Student Services or General Education buildings. However, space constraints may make this challenging.

For Diablo Valley College, a central plant may be feasible as part of the new academic complex, which is planned for construction in 2030. this central plant could then be available to serve the renovation projects as they occur in the later 2030's.

Utilizing a central plant, as opposed to each building having standalone heating and cooling equipment, offers many benefits in terms of efficiency, redundancy, and heat recovery. Centralizing the load of multiple buildings offers diversity in the load profile, which may allow for energy to be recovered (using heat recovery heat pumps) when simultaneous heating and cooling loads are required across a campus. Central plant equipment can be designed with proper modularity to allow for very efficient part load operation, as well as inherent redundancy. Thermal storage systems can be readily added to a central plant, allowing primary heating and cooling equipment to be dramatically downsized, as well as offering the ability to load shift to times when energy is cheap or when the grid is the cleanest (depending on District priority).

The downsides of a central plant approach are primarily cost and complexity. A significant infrastructure investment is required to install the initial phases of a central plant, sizing piping and electrical systems for their anticipated future loads. However, future buildings that connect to the central plant will be lower cost. The equipment is typically of a larger scale, often requiring specialized contractors to perform major maintenance. A relatively large area is often required to house the central plant equipment, which can be challenging for some campuses.



HVAC Electrification Strategy

Central Plant Opportunities – San Ramon Center

The San Ramon Center may be a prime target for electrification of its central plant. The assessment report indicates that the boilers still have 12 years of remaining life, however the chilled water system is nearing the end of its life. The cooling tower is indicated with 0 years remaining, while the chiller still has 5 years.

The SRC's central plant utilizes nominally 86% efficient natural gas boilers to deliver 180F (140F return) hot water (140F return) to the buildings. The plant's current total heating capacity is 3,440 MBH, with expansion to 6,880 MBH planned into the piping system.

The chilled water system is comprised of 2 water-cooled chillers with a total of capacity of 645 Tons (7,740 MBH) and 2 cooling towers of 700 Tons capacity.

A transcritical heat pump (TCHP) may be an ideal solution to directly replace the boilers while also providing a portion of the cooling load. When simultaneous heating and cooling loads are present, the TCHP is able to operate in heat recovery mode to meet both demands with an extremely high efficiency (total COPs above 7). ASHPs may also be a viable solution if water temperatures can successfully be reduced.


A high-level design concept is to, at the end of the life of the chilled water system, replace the 3,440 MBH of boiler capacity with an equivalent capacity of TCHP. This would also provide approximately 2,900 MBH of cooling (~240 Tons). The two existing water-cooled chillers are replaced with one high efficiency water-cooled chiller to meet the remaining load of approximately 400 Tons. This approach would dramatically reduce the EUI and carbon emissions of the facility, as well as reduce water consumption from cooling tower evaporation and blowdown.

Combined with thermal storage (hot and/or cold water), a TCHP plant can utilize load shifting strategies to reduce energy demand charges and more effectively leverage heat recovery. Carbon emissions can also be greatly reduced by shifting the load to times when the grid is cleanest or when onsite renewable energy production is plentiful.

Thermal energy storage systems, like solar PV systems may be eligible to have 30-40% of their costs covered by the Inflation Reduction Act (IRA).

HVAC Electrification Strategy

Diablo Valley College



HVAC Electrification Strategy

Diablo Valley College – FMP Projects Pt.1

The 2024 Facilities Master Plan identifies 12 projects that will enhance the usability of the campus. These projects include new construction of 6 new buildings, 4 of which occur during the timeline of the energy study.

As part of the 4CD sustainability goals, each of these new buildings will be all-electric and LEED gold certified. The predicted EUI of these buildings is shown in the table below, along with the assumptions of building size and what year the projects will be built.

| New Construction Projects | | | | | |
|-------------------------------|------------|----------------------|----------------------------|--------------------------------------|---|
| Building | Area (ft2) | Year of Construction | Predicted EUI (kBtu/sf-yr) | Annual Electricity Consumption (kWH) | Notes |
| NEW SCIENCE COMPLEX | 18,500 | 2031 | 50 | 271,091 | Coincides with demolition of science center and planetarium buildings |
| NEW ACADEMIC COMPLEX | 69,000 | 2030 | 25 | 505,548 | Coincides with the demolition of Faculty Office, Liberal Arts building, and Administration Building |
| NEW EARLY CHILDHOOD EDUCATION | 11,300 | 2027 | 25 | 82,793 | Replaces North and South Early Childhood Education buildings |
| BOOKSTORE EXPANSION | 7,375 | 2028 | 30 | 64,842 | Numbers provided are for just the expanded area and the addition is assumed to be supplied its own separate ASHP electric heating, LEDs and ALC |

Additional projects in the MFP outside of the scope of the energy study are the new Inter-disciplinary Building and new Police and Safety Services building.

HVAC Electrification Strategy

Diablo Valley College – FMP Projects Pt.2

The 2024 Facilities Master Plan identifies 12 projects that will enhance the usability of the campus. These projects include 6 renovations. None of those renovations occur during the period of time of the energy study, but the bookstore addition also coincides with a renovation of the existing facility, so the energy impact of that portion of the bookstore project is shown below.

Renovation projects are anticipated to eliminate natural gas from the HVAC and plumbing systems, resulting in a substantial energy and carbon emissions reduction. These savings are summarized in the table below.

| Renovation Projects | | | | | | | |
|---------------------|------------|--------------------|--------------|----------------------------|------------------------------|-----------------------------|--|
| Building | Area (ft2) | Year of Renovation | Existing EUI | Predicted EUI (kBtu/sf-yr) | Natural Gas Reduction (kBtu) | Electricity Reduction (kWh) | Notes |
| BOOKSTORE | 13,462 | 2028 | 53.9 | 30.9 | 356,205 | 17,438 | Electrification, LEDS and Controls included in FMP renovation. Numbers shown are for existing portion of the building. |

Renovations of the following buildings occur after and outside our energy plan:

- Humanities
- Library
- Math
- Performing Arts
- Music
- M&O/Warehouse

HVAC Electrification Strategy

Diablo Valley College – Additional Efficiency Projects

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|--------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|--|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| POOL | NA | 2030 | | | x (Boiler) | Unkown | | | \$750,000 | \$750,000 | NA | 0 | NA | NA |
| SCIENCE & TECHNOLOGY | 19,505 | 2033 | x | x | x (Boiler) | AHU at 0, Boiler not in inventory | \$289,863 | \$434,794 | \$869,589 | \$1,594,246 | 10,893 | 653,422 | 66.5 | 31.0 |
| HUMANITIES | 16,428 | 2026 | x | x | x (Furnace) | Furnaces with 2-3 years of RUL | \$179,398 | \$269,097 | \$448,495 | \$896,989 | -2,150 | 658,536 | 105.4 | 65.8 |
| LIFE SCIENCES | 33,844 | 2034 | x | x | x (Boiler) | Boiler and two of 3 AHUs have 10 years. One AHU has 5 | \$525,587 | \$788,380 | \$1,576,761 | \$2,890,728 | -34,800 | 1,646,849 | 127.4 | 82.2 |
| LIBRARY | 63,201 | 2027 | x | | x (Boiler) | Boiler age unknown | \$721,228 | | \$2,163,685 | \$2,884,914 | -173,325 | 1,655,945 | 60.4 | 43.6 |
| ENGINEERING TECHNOLOGY | 36,551 | 2026 | x | x | x (Furnace) | AHUs at one, non-FMP ALC + LED + electrification plus HVAC improvement due to very high existing building HVAC EUI | \$399,146 | \$598,719 | \$997,865 | \$1,995,730 | -181,945 | 3,157,794 | 136.8 | 67.4 |
| LEARNING CENTER | 15,914 | 2032 | x | x | x (Furnace) | Several AHUs at 0 years left | \$226,313 | \$339,470 | \$565,783 | \$1,131,565 | 22,916 | 553,871 | 86.9 | 50.7 |

*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.

HVAC Electrification Strategy

Diablo Valley College – Additional Efficiency Projects Cont.

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|----------------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|--|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| STUDENT UNION | 12,744 | 2027 | x | x | x (Furnace) | Severall AHUs at 0 and 2 of remaining useful life | \$145,430 | \$218,145 | \$363,576 | \$727,151 | -3,063 | 524,186 | 76.4 | 36.0 |
| MATH BUILDING | 24,211 | 2031 | x | x | x (Boiler) | 8 Years left on boiler | \$329,478 | \$494,217 | \$988,435 | \$1,812,130 | 30,805 | 645,945 | 55.8 | 24.8 |
| PHYSICAL SCIENCE | 41,220 | 2025 | x | x | x (Boiler) | Boiler at 0, AHUs at 7, of remaining useful life | \$430,749 | \$646,124 | \$1,292,247 | \$2,369,120 | -34,610 | 1,931,487 | 125.0 | 81.1 |
| BUSINESS & WORLD LANGUAGE | 26,676 | 2026 | x | x | x (Boiler) | Boiler at 0, AHUs at 7, of remaining useful life | \$291,309 | \$436,963 | \$873,926 | \$1,602,197 | 40,255 | 651,396 | 68.8 | 39.3 |
| POLICE & SAFETY SERVICES | 2,880 | 2026 | x | | | 5 years of remaining useful life on HVAC Equipment, LED is only energy related recommended project | \$31,450 | | | \$31,450 | 8,829 | 0 | 44.7 | 34.3 |
| STUDENT SERVICES | 41,103 | 2034 | x | x | x (Boiler) | AHU at 10 years of remaining useful life, Boiler is from HSF 119 and in good shape | \$638,317 | \$957,476 | See HSF Below | \$1,595,793 | 57,787 | 1,044,184 | 63.8 | 33.6 |
| HOSPITALITY STUDIES & FOOD COURT | 44,779 | 2034 | x | x | x (Boiler) | Equipment is in good shape, boiler also serves Student Services 118 | \$695,404 | \$1,043,106 | \$4,001,164 | \$5,739,674 | 50,798 | 1,253,717 | 64.0 | 32.2 |

*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.

HVAC Electrification Strategy

Diablo Valley College – Additional Efficiency Projects Cont.

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|--------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|---|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| PERFORMING ARTS | 34,423 | 2032 | | | x (Boiler) | 8 years of remaining useful life on boiler | | | \$1,468,589 | \$1,468,589 | -101,065 | 965,573 | 42.7 | 24.7 |
| MUSIC | 14,522 | 2030 | x | | | 14 years of remaining useful life on the boiler | \$189,114 | | | \$189,114 | 44,518 | 0 | 65.1 | 54.6 |


*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.

HVAC Electrification Strategy

Diablo Valley College– District Energy Project Savings and Cost Summary

| Non-FMP Energy Projects Cumulative Cost | | | | Non-FMP Energy Project Annual Cost Savings (2023 DVC Utility Rates) | | | | |
|---|-------------|-----------------|--------------|---|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting | Controls | Electrification | Total | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| \$5,092,787 | \$6,226,491 | \$16,360,113 | \$27,679,391 | \$ 265,435 | \$ 68,811 | \$ 323,481 | -\$402,638 | \$255,089 |

| Non-FMP Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | | Non-FMP Energy Project Annual Cost Savings (2035 Estimated DVC Utility Rates) | | | | |
|--|--------------------------|----------------------------|----------------------------|---|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| 4,116,826 | 1,067,245 | 11,240,652 | 17,485,458 | \$ 474,005 | \$ 122,881 | \$ 577,662 | -\$719,018 | \$455,530 |




HVAC Electrification Strategy


Diablo Valley College– District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. PV provides a greater source of averted emissions early on, while electrification provides a greater amount of averted emissions by the end of the study. This is due to the improving grid emissions rate lowering the offset impact of PV and increasing the gas replacement impact of electrification. There is also PV at the start of the study, whereas it takes time for a portfolio of electrified buildings to accumulate.

Metric Tons of CO2 Averted, by Measure



Emissions Averted from 2026 to 2040 (15 Years - Metric Tons of CO2)



HVAC Electrification Strategy

San Ramon Center– New Construction

The following building is planned to be constructed at the San Ramon campus in the 2024 FMP.

| New Construction Projects | | | | | |
|-------------------------------------|------------|----------------------|----------------------------|--------------------------------------|----------------------|
| Building | Area (ft2) | Year of Construction | Predicted EUI (kBtu/sf-yr) | Annual Electricity Consumption (kWH) | Notes |
| SRC SCIENCE / STEM PATHWAY BUILDING | 15,000 | 2028 | 50 | 219,803 | New Science Building |

HVAC Electrification Strategy

San Ramon Center – Additional Efficiency Projects

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|----------------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|--|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| SAN RAMON CAMPUS | 76,528 | 2029 | x | x | X (Boiler) | 12 years of RUL for boiler, same boiler replace from central plant as Library Learning Resource Center | \$953,678 | \$1,430,517 | \$2,861,034 | \$5,245,230 | 36,713 | 2,621,282 | 83.5 | 47.6 |
| LIBRARY LEARNING RESOURCE CENTER | 8,842 | 2029 | | | X (Boiler) | 12 years RUL for boiler, same boiler replace from central plant as San Ramon Campus | | | \$330,562 | \$330,562 | -88,779 | 248,582 | 55.5 | 37.4 |

*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.

HVAC Electrification Strategy

San Ramon Center – District Energy Project Savings and Cost Summary

| SRC Energy Projects Cumulative Cost | | | |
|-------------------------------------|-------------|-----------------|-------------|
| Lighting | Controls | Electrification | Total |
| \$953,678 | \$1,430,517 | \$3,191,597 | \$5,575,792 |

| SRC Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | |
|--|--------------------------|----------------------------|----------------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) |
| 800,483 | 260,960 | 1,844,913 | 2,869,864 |

| 2023 SRC Energy Project Energy Cost Savings (Annual Impact - Not Cumulative) | | | | |
|--|------------------|----------------------------------|-----------------------------|----------------------|
| Lighting Savings | Controls Savings | Electrification Electric Penalty | Electrification Gas Savings | Total Annual Savings |
| \$56,304 | \$18,355 | -\$129,766 | \$60,554 | \$5,447 |

| 2035 SRC Energy Project Energy Cost Savings (Annual Impact - Not Cumulative) | | | | |
|--|------------------|----------------------------------|-----------------------------|----------------------|
| Lighting Savings | Controls Savings | Electrification Electric Penalty | Electrification Gas Savings | Total Annual Savings |
| \$100,545 | \$32,778 | -\$231,731 | \$108,136 | \$9,727 |


All of the San Ramon Center projects are scheduled for 2029.

HVAC Electrification Strategy


San Ramon Center– District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. PV provides the most benefits in the initial years of the study, but the electrification component becomes more impactful as the electric emissions rate associated with the campus decreases.

Metric Tons of CO2 Averted, by Measure



Emissions Averted from 2026 to 2040 (15 Years - Metric Tons of CO2)



Energy Timeline




HVAC Electrification Strategy

Diablo Valley College – Campus EUI Trend

Overall, electrification is very important to achieving campus EUI and emissions goals, as large reductions in gas kBTU results in much smaller increases in electric kBTU. This campus presents an opportunity to reduce EUIs below the district 2030 and 2035 targets in order to reduce the district wide average to meet the target. The electrification that results in these high EUI reductions is also important for this campuses emissions reduction, since the PV has a relatively low carbon impact.


Campus EUI (kBTU/sf-yr) by Type (Excluding Renewables)



HVAC Electrification Strategy

Diablo Valley College – Campus Utility Costs Trend

The chart below shows the total and fuel specific utility costs for the campus going forwards. This is based on an assumption of a 4% escalation of electricity and gas costs per year, as well as the campus being in a net metering scheme which allows for the PV kWh to have the same value as electric consumption kWh. The 2022 use with escalated electricity and gas costs are also shown with a dotted line, to show the impact of the cumulative interventions performed on the campus. Renewables and efficiency upgrades like controls and LEDs reduce the operating cost of the campus. The 3.844 MW of additional future PV required to offset emissions by 2035 would result in an estimated additional 2.27 million dollars a year of cost savings with 2035 utility rates.




Planned PV is assumed to be installed in the year prior to the start of 2026.

HVAC Electrification Strategy

Diablo Valley College – Campus Emissions Trend

The graph below shows the emissions trend accounting FMP and non-FMP projects. Emissions offset by renewables deprecate over time due to decreasing grid emissions. Emissions from electrical consumption deprecate at the same rate. The starting emissions are based on weather normalized data. About 3.84 MW of additional future PV would be required to bring these emissions down to zero in 2035. Otherwise, to meet the goal, offsets would need to be purchased until the California grid is legislated to be emissions free by 2045. This amount would start at about 1,100 tons per year in 2035 and decrease to about 600 tons per year by 2040 as the grid approaches the legislative targets. If the CA grid/Constellation emissions rate approaches zero carbon faster or slower than legislatively required, the offsets required could go up or down. A good efficiency and emissions reduction strategy may not require each individual campus to meet the sustainability goals, but rather the ensemble of campuses meeting the goals. This will allow for taking advantage of deploying PV where it is most effective (campuses associated with higher emitting utilities) or where there is the most capacity, and purchasing offsets or clean energy at a district level for the net emissions that remain. There is a small amount of ongoing gas use associated with the Music building which was not electrified due to the large remaining useful life of the gas boiler and relatively low impact of the building. This is easy to offset with PV, but ought to be dealt with in the early 2040's when the equipment is at the end of its life and the FMP phase 2 calls for work on this building.




HVAC Electrification Strategy

San Ramon Center - Energy and Emissions Information

Information regarding the San Ramon facility and its role in the overall campus emissions and EUI reduction will be included in the district wide version of the report. Below are graphs of the EUI and emissions of the facility over time, without goals or PV/Carbon Offset/Purchased Green Energy interventions. We have also included data for an electrification/LED project associated with the facility. Due to the San Ramon Center's high electric grid emissions rate, more CO2 reduction comes from future grid improvements than directly from electrification. The SRC Science Center is a new building planned to be constructed in the FMP.


SRC Campus EUI (kBTU/sf-yr)



*This is a new building as part of the FMP that doesn't currently exist on the campus

| SRC/SRC Library Electrification and ALC/LED Upgrade (ALC/LED only for main building) | | | | | | | |
|--|------|-------------|--------------|-----------|-----------------------|--------------------|------------------------------------|
| Area | Year | Cost | Starting EUI | EUI After | Electric kWh Increase | Gas kBTU reduction | Annual Cost Savings (2029 Dollars) |
| 85,370 | 2029 | \$5,575,792 | 80.6 | 46.5 | 52,066 | 2,869,864 | \$67,826 |


SRC Campus Emissions (Metric Tons CO2 - Renewables Excluded)



HVAC Electrification Strategy

San Ramon Center– Campus Utility Costs Trend

The chart below shows the total and fuel specific utility costs for the San Ramon Center going forwards. This is based on an assumption of a 4% escalation of electricity and gas costs per year, as well as the campus being in a net metering scheme which allows for the PV kWh to have the same value as electric consumption kWh. The 2022 use with escalated electricity and gas costs are also shown with a dotted line, to show the impact of the cumulative interventions performed on the campus. Renewables and efficiency upgrades like controls and LEDs reduce the operating cost of the campus. The 433 kW of additional PV required to offset emissions by 2035 would result in an estimated additional 278 thousand dollars a year of cost savings with 2035 utility rates.




Planned PV is assumed to be installed in the year prior to the start of 2026.

HVAC Electrification Strategy

San Ramon Center – Campus Emissions Trend

The graph below shows the emissions trend accounting FMP and non-FMP projects. Emissions offset by renewables deprecate over time due to decreasing grid emissions. The campus would need 433 additional kW of PV to offset its emissions completely in 2035.




4.

District Office

Carbon and Energy Benchmarking




DO EUI (kBtu/sf)



■ Building Elec EUI ■ Building Gas EUI ■ Site Elec EUI

DO 2022 Weather Normalized Campus Emissions Breakdown



■ Total Elec Emissions ■ Total Building Gas Emissions

District Offices/Education Center

Campus-Level Benchmarking

The District Offices facility is associated with Constellation and as an emissions rate of 701 lbs CO₂e per MWH of electricity. The facility is 46,500 sf.

District Offices Building Benchmark Data Summary

| Building | Age | Area | EUI | Gas EUI | Total kBTU | Gas kBTU | Elec kBTU | Gas Carbon Emissions (kg CO2) | Electricity Carbon Emissions | Total Carbon Emissions (Kg CO2e) |
|------------------|------|--------|------|---------|------------|-----------|-----------|-------------------------------|------------------------------|----------------------------------|
| EDUCATION CENTER | 1973 | 46,521 | 65.5 | 18.2 | 47.3 | 3,048,232 | 847,506 | 2,200,726 | 99,006 | 452,010 |

Electric Infrastructure Assessment



Electrical Infrastructure Assessment - Introduction

As part of the Electrification Plan, Interface Engineering evaluated the available electrical system capacity at each campus to accommodate the future electrical demands from electrification, renewable energy deployment, and EV charging. The goal of this assessment is to confirm the capacity at the main campus feeders and switchgear. Downstream equipment, such as panels, wiring, and transformers, are not included in this assessment.

We have assessed the available electrical capacity at each of the District's campuses, as well as the District Offices and Brentwood Building. The available capacity has been evaluated using PG&E utility data (15-minute interval data) and PV inverter output data (hourly data provided from the district) for the period of May 2022 through August 2023.


For electrical services that include PV production, the generation data from net generation output (NGOM) meters and/or direct inverter output data is added to the consumption data reported at the main revenue meter, establishing the true demand on the service.

The demand (kW) reported for each service is a calculated value, using the consumption and PV production data (kWh). For example, if 100 kWh are consumed in a 15-min timestep, then the calculated demand for that timestep would be reported as 400 kW (100 kWh X (1/4 hours)).


District Offices

- District office is powered by an existing 1000A, 480V service with a total capacity of 831.4kW. The maximum demand on this service was 211.9kW.
- District Office data appears complete.
- The existing service has an available capacity of 68.1%, or 566.5kW.

| Electrical Capacity Calculation | | |
|---------------------------------|----------------------------------|-----------------|
| 1 | Top 0.1% of Demand | 192.0 kW |
| 2 | Maximum Demand | 211.9 kW |
| 3 | Maximum Demand Occurrence | 8/17/2023 13:45 |
| 4 | Service Voltage | 480 V |
| 5 | Service Amperage | 1000 A |
| 6 | Service Capacity | 831.4 kW |
| 7 | Maximum Demand [2] | 211.9 kW |
| 8 | Maximum Demand * 125% | 264.9 kW |
| 9 | Available Capacity [6-8] | 566.5 kW |
| 10 | Percent Available Capacity [9/6] | 68.1% |



District Offices Single Line Diagram



Renewable Energy Deployment



Renewable Energy Deployment Strategy

Introduction

On-site renewable energy generation is a critical component of 4CD’s sustainability plan to achieve net zero carbon emissions by 2035. The district currently has approximately 3.2 MW of photovoltaic (PV) solar panel systems across CCC, DVC, and LMC, which produce nearly 3.8 MWh annually. This represents approximately 19% of the district’s electricity consumption.

As part of its plan to increase on-site renewable production, 4CD has five additional PV projects approved by PG&E for installation but have yet to be funded. For the purposes of estimating the impact of these approved projects, it is assumed that these systems will be installed in 2026. An estimate of the total development costs are shown in the table below, which based on the information provided by Sage Renewables. These costs are based on recent quote that 4CD received for the Brentwood system, which indicated a total cost of \$7.87/watt for carport arrays. The Brentwood, DVC, and LMC installations are also planned to include battery energy storage systems (BESS), which will further enhance the cost reduction capabilities of these systems.

The tables to the right summarize the existing and planned PV systems, including their DC capacity, orientation and expected annual production rate (which vary slightly by campus and by array orientation). The table at the bottom indicates the % of electrical consumption that is met with the existing and future PV systems.

The campus site plans on the subsequent slides indicate the existing and planned PV locations on each campus, including the context of the newly planned buildings as part of the FMP. The site plans also indicate areas that may potentially be used for additional PV in the future.

The energy and carbon impact of the existing and planned arrays are discussed in more detail in the “District Energy and Carbon Timeline” chapter of this report.

The table below shows the future PV, beyond what is currently planned, that would be required in order to achieve net zero emissions for the specific campuses in 2035, and the associated cost of deployment in 2024 PV costs.

| Future PV Summary (Scenario A) | | | | | |
|--------------------------------|-----------|--------------|---------------------------------|--|--------------------------------|
| Campus | Size (kW) | Cost* | Est. Annual Production (kWh/yr) | Predicted Electrical Consumption in 2035 | % Future Load Met by Future PV |
| DVC | 3,844 | \$30,252,280 | 5,766,000 | 8,782,110 | 66% |
| CCC | 2,167** | \$17,054,290 | 3,250,500 | 5,143,509 | 63% |
| LMC | 591 | \$4,651,170 | 886,500 | 4,276,119 | 21% |
| SRC | 433 | \$3,407,710 | 649,500 | 1,413,618 | 46% |
| DO | 468*** | \$3,683,160 | 702,000 | 701,838 | 100% |
| BEC | 166 | \$1,306,420 | 249,000 | 749,521 | 33% |

*costs are based on estimates for PV projects for the district in 2024
**based on offsetting kWh instead of carbon emissions, due to the utility split for CCC between MCE and Constellation
***Due to limited space at this facility, this PV could be installed on another Constellation Campus like DVC, LMC, or SRC to have the same effect.

| Existing PV systems | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | Kwh/KW* | Annual Energy Production (kWh) |
| Contra Costa College - Lot 9 | 403 | 225 | 1053 | 424,359 |
| Diablo Valley College - Lot 1 | 567 | 270 | 1297 | 735,289 |
| Diablo Valley College - Lot 3 | 267 | 270 | 1297 | 346,247 |
| Diablo Valley College - Lot 4 | 548 | 270 | 1297 | 710,650 |
| Los Medanos College - Lot B | 763 | 150 | 1139 | 868,904 |
| Los Medanos College - Lot C | 638 | 230 | 1128 | 719,953 |
| Total | 3,186 | | | 3,805,402 |

*The existing PV production rates are 20-30% below the expected rate, based on the location and orientation of the systems. This may indicate performance issues with the panels and inverters.

| Planned PV systems | | | | | |
|-------------------------------|--------------------|------------------------------|--------|--------------------------------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | kWh/KW | Annual Energy Production (kWh) | Project Development Costs (\$) |
| Diablo Valley College - Lot 5 | 878 | 270 | 1564 | 1,373,000 | \$6,909,860 |
| Contra Costa College - Lot 1 | 947 | 225 | 1551 | 1,469,000 | \$7,452,890 |
| Los Medanos College | 1,154 | 150 | 1560 | 1,800,000 | \$9,081,980 |
| San Ramon Center - Main Lot | 483 | 225 | 1580 | 763,000 | \$3,801,210 |
| Brentwood Center - Main Lot | 322 | 180 | 1556 | 501,032 | \$2,534,140 |
| Total | 3,784 | | | 5,906,032 | \$29,780,080 |

| Renewable Energy Summary | | | | |
|--------------------------|---------------------------------------|----------------------|---------------------|---------------------------|
| | Annual Electricity Consumption (kWh)* | % Met by Existing PV | % Met by Planned PV | Total Planned Renewable % |
| CCC | 4,414,407 | 10% | 33% | 43% |
| DVC | 8,618,555 | 21% | 16% | 37% |
| LMC | 4,783,853 | 33% | 38% | 71% |
| SRC | 1,200,248 | 0% | 64% | 64% |
| Brentwood | 573,479 | 0% | 87% | 87% |
| District Offices | 657,697 | 0% | 0% | 0% |
| District | 20,248,239 | 19% | 28% | 47% |

*True 2022 value that is not weather normalized

District Office/Education Center

PV Offset



As an existing building with unknown structural conditions and limited roof and parking area, there are no recommendations to install PV at this site. However, in order to meet emissions targets, PV could be installed at another campus being served by the same utility in order to offset the emissions and electricity associated with this building.



Potential Future Offsite System

- 468 KW
- Future PV sized based on remaining electrical consumption and emissions in 2035 projections
- Approximately 23.5k ft² panel area, based on current PV technology

District Energy Projects



Electrification Plan Introduction

In 2022, more than 48% of the electricity delivered by California's grid was generated by renewable sources such as solar photovoltaics, wind, biomass, and hydroelectric. This percentage will increase over time, as state laws such as SB100 mandate that CA's grid achieve 100% carbon-free generation by 2045. This means that by electrifying legacy natural gas heating systems, the carbon footprint associated with these loads will trend towards zero. For the Contra Costa Community College district in 2022, ~45% of its electricity was provided by renewable resources (including grid-supplied and on-site generation).

The purpose of this study is to support the master-planning effort for the Contra Costa Community College District (4CD) with a district-wide electrification plan. The plan provides an analysis of how electrifying the district's natural gas heating systems and deploying renewable energy systems will reduce the district's energy consumption and carbon footprint.

The primary goal of the electrification plan is to assist the district in meeting its sustainability goals, as outlined in the "2022 4CD District Wide Energy & Sustainability Goals" document.

The electrification plan consists of the following components:

- Building Benchmarking Report
- Electrical Systems Assessment
- Campus Photovoltaic Deployment Assessment.
- Building Electrification Strategy
- District Energy and Carbon Timeline

4CD has adopted a set of sustainability goals which target significant reductions in carbon emissions across the entire organization by 2035. The electrification study addresses the greenhouse gas (GHG) and renewable energy goals by proposing and quantifying the impacts of building replacement and renovation projects, renewable energy systems, as well as additional efficiency projects such as LED lighting, building management controls, metering upgrades and HVAC electrification.

4CD's goals are focused on the two primary dates of 2030 and 2035. The 2030 goals include reducing GHG emissions by 75% below the 2013 baseline and reducing the district energy use intensity (EUI) by 25%. The 2035 goals include reducing GHG emissions by 100% and reducing district EUI by 40%.

HVAC Electrification Strategy

Contra Costa Community College District has adopted a broad set of sustainability goals and practices that will result in dramatic reductions in energy consumption and carbon emissions from its buildings. A key component of these goals is the requirement that all newly constructed buildings are all-electric (no fossil fuel combustion used for space heating). This approach leverages the fact that California's grid is becoming cleaner (emitting less carbon) each year, which inherently reduces the carbon footprint of the campus.

There are a range of all-electric heating technologies that work well for new construction projects. However, converting the existing natural gas heating systems to all-electric has historically been challenging from a technological and financial standpoint. Air-source heat pump (ASHP) technology which use traditional refrigerants have limitations on the temperatures they can produce (typically a maximum supply temperature of approximately 130F), which may make them incompatible with typical legacy heating systems which utilize 160-180F temperatures. The renovations required to make existing buildings compatible with ASHP technology can be prohibitively expensive. These renovations may require replacement of some heating coils to accommodate lower water temperature, and often piping/coupling systems need to also be replaced. Furthermore, ASHP technology is limited to a lower ambient temperature of ~25F, which means that supplemental heating may be required on the coldest days of the year.

Water-source heat pumps (WSHP) are more flexible, with supply temperatures as high as 170F. These require a water-based heat source/sink, such as a ground loop via a geo-exchange system. Geo-exchange systems are often very costly due to the cost of drilling vertical wells or excavating for horizontal systems. These costs and space constraints typically preclude water-source heat pumps as a retrofit solution.

Transcritical heat pump (TCHP) technology is relatively new to building comfort heating and cooling which is addressing the traditional challenges of ASHPs and WSHPs. This technology utilizes CO₂ as its refrigerant (known as R744), which enables hot water delivery temperatures of 180F at outdoor ambient conditions down to -15F. This allows "direct replacement" of natural gas boilers and domestic hot water heaters. This technology is still "emerging", with a limited number of installations in the U.S., however, it is expected that this technology will develop rapidly over the next 5 years.

For existing buildings with traditional boiler-based hydronic systems, an assessment process is recommended to determine what modifications are required in order to electrify these systems with the highest possible efficiency. The primary goal of this assessment is to determine if the existing hydronic systems is capable of operating at lower heating hot water temperatures while still maintaining design temperatures. Lowering the hot water temperatures allows for compatibility with a wider range of heat pump technology, and also allows them to operate much more efficiently. The following bullet points outline the assessment process:

- Review heating coils configuration - heating coil performance will be reduced when operating at lower hot water temperatures, however, in some cases, this performance derating can be overcome with modification to control sequences. In most cases, two-row heating coils at air handling units and VAV boxes can be utilized when lowering hot water temperatures from 180F to 140F, or even lower. The peak capacity of the coils is reduced with lower water temperatures, but simply increasing the warm-up time of the building may overcome these limitations. Also, reducing the temperature setback of the space will reduce the load that the coils must meet. Single-row coils will likely struggle to meet the load with reduced water temperatures and may need to be replaced.
- Conduct a hot water reset investigation – During the winter months, reduce the heating hot water temperature in 5-degree increments for one to two weeks at a time. This process will reveal which zones/coils are able to meet space loads with reduced water temperatures. As zones are discovered to be out of setpoint, increase the warm-up period or limit the temperature setback. Continue to reduce water temperatures and increase warmup period to determine if a lower water temperature will allow the building to maintain functionality. This process may reveal that certain zones/coils will function adequately, while others may need to be upgraded. The desired outcome of the reset investigation is a custom outdoor air reset control sequence that reduces hot water temperatures to a minimum, as a function of outside air temperature. For example, the goal may be to operate at 140F supply/ 100F return as often as possible but allows for increases up to 180F supply / 140F return on the coldest days of the year.

HVAC Electrification Strategy

Transcritical Heat Pumps

While this heat pump technology has long been used in commercial refrigeration for 20 years or more, it is more recently being applied to building HVAC and domestic hot water. Typically, these machines use CO₂, or R-744, as its refrigerant, which has a global warming potential (GWP) of 1, which is far below traditional refrigerants like R-410a (GWP of 2088) or R-134a (GWP of 1430). Furthermore, R-744 is able to operate with much higher temperatures, at or above 180F. However, like traditional heat pumps, transcritical heat pumps operate much more efficiently with lower supply water temperatures.

As the technology continues to advance, it may become a critical component of electrifying existing buildings that utilize hydronic heating. The graph on the right shows the efficiency curves for various operating conditions for Flow Environmental System’s model H transcritical heat pump. These trends show that while operating at “traditional” boiler system temperatures of 180F supply / 140F return, a COP of 1.75 is achieved. However, lowering the supply temperature to 140F dramatically improves efficiency, approaching a COP of 3.5. This highlights the importance of the hot water reset assessment process outline on the previous page.


Transcritical heat pump technology is also well suited for domestic hot water applications, where storage temperatures typically range from 125F – 140F. Systems like Sanden and Lync are able to achieve COPs above 5, which allows for significant improvements to operation cost and carbon emissions associated with domestic hot water.

The links below are examples of transcritical heat pump technology that are recommended for investigation by future design teams for use in both new construction and retrofit projects.

<https://www.flowenvirosys.com/products>

<https://www.smallplanetsupply.com/sanc02>

<https://www.lyncbywatts.com/>



HVAC Electrification Strategy

District Offices – Additional Efficiency Projects

The following matrix outlines the energy efficiency upgrades planned in order to meet the district energy and sustainability goals.

| Cost Assumptions | Construction Cost Assumptions (\$/sf) (2024) (costs escalated 4.5% per annum) |
|---------------------------------------|---|
| Lighting Retrofit | \$10 |
| Controls Retrofit | \$15 |
| Electrification – Boiler Replacement | \$30 |
| Electrification – Furnace Replacement | \$25 |

| District Energy Projects | | | | | | | | | | | | | | |
|--------------------------|------------|--------------|----------------------------|----------------------------|--------------------------|---|------------------------|------------------------|----------------------|-------------|-------------------------|--------------------|--------------|-----------|
| Building | Area (ft2) | Project Year | Lighting Retrofit Required | Controls Retrofit Required | Electrification Required | Remaining Useful Life on Primary Mechanical Equipment | Lighting Retrofit Cost | Controls Retrofit Cost | Electrification Cost | Total Cost | Electric Reduction* kWh | Gas Reduction kBTU | Starting EUI | EUI After |
| EDUCATION CENTER | 46,521 | 2031 | | x | X (Boiler) | Unknown boiler age | | \$949,630 | \$1,899,260 | \$2,848,889 | -42,215 | 847,506 | 65.5 | 50.4 |

*Electrified projects tend to have a negative reduction in kWh, an increase, due to the conversion of gas to electric load. Projects with ALC and or LED upgrades and no electrification will have a positive decrease in kWh.

HVAC Electrification Strategy

District Office/Education Center – District Energy Project Savings and Cost Summary

| DO Energy Projects Cumulative Cost | | | |
|------------------------------------|-----------|-----------------|-------------|
| Lighting | Controls | Electrification | Total |
| \$0 | \$949,630 | \$1,899,260 | \$2,848,889 |

| DO Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | |
|---|--------------------------|----------------------------|----------------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) |
| 486,610 | 0 | 1,052,172 | 1,636,712 |

| 2023 DO Energy Project Energy Cost Savings (Annual Impact - Not Cumulative) | | | | |
|---|------------------|----------------------------------|-----------------------------|----------------------|
| Lighting Savings | Controls Savings | Electrification Electric Penalty | Electrification Gas Savings | Total Annual Savings |
| \$37,079 | \$0 | -\$80,174 | \$36,990 | -\$6,105 |

| 2035 DO Energy Project Energy Cost Savings (Annual Impact - Not Cumulative) | | | | |
|---|------------------|----------------------------------|-----------------------------|----------------------|
| Lighting Savings | Controls Savings | Electrification Electric Penalty | Electrification Gas Savings | Total Annual Savings |
| \$66,214 | \$0 | -\$143,172 | \$66,055 | -\$10,903 |


All of the District Office projects are scheduled for 2031.

HVAC Electrification Strategy


District Offices/Education Center– District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. The electrification component of the recommended energy project averts more emissions than the controls upgrade component.

Metric Tons of CO2 Averted, by Measure



Emissions Averted from 2026 to 2040 (15 Years - Metric Tons of CO2)



Energy Timeline




HVAC Electrification Strategy


District Offices/Education Center - Energy and Emissions Information

Information regarding the District Offices facility and its role in the overall campus emissions and EUI reduction will be included in the district wide version of the report. Below are graphs of the EUI and emissions of the facility over time, without goals or PV/Carbon Offset/Purchased Green Energy interventions. We have also included data for an electrification project associated with the facility. Due to the District Offices high electric grid emissions rate, more CO2 reduction comes from future grid improvements than directly from electrification.

District Offices EUI (kBtu/sf-yr)



District Offices Annual Emissions (Metric tons of CO2)




District Offices/Education Center Electrification and Controls Upgrade

| Area | Year | Cost | Starting EUI | EUI After | Electric kWh Increase | Gas kBtu reduction | Annual Cost Savings (2031 Dollars) |
|------|------|-------------|--------------|-----------|-----------------------|--------------------|------------------------------------|
| | 2031 | \$2,848,889 | 66 | 50 | 42,215 | 847,506 | \$12,483 |

HVAC Electrification Strategy

District Offices/Education Center– Facility Utility Costs Trend

The chart below shows the total and fuel specific utility costs for the District Office Facility going forwards. This is based on an assumption of a 4% escalation of electricity and gas costs per year, as well as the campus being in a net metering scheme which allows for the PV kWh to have the same value as electric consumption kWh. The 2022 use with escalated electricity and gas costs are also shown with a dotted line, to show the impact of the cumulative interventions performed on the campus.




Planned PV is assumed to be installed in the year prior to the start of 2026.

HVAC Electrification Strategy

District Offices/Education Center– Campus Emissions Trend

The graph below shows the emissions trend accounting FMP and non-FMP projects. Emissions offset by renewables deprecate over time due to decreasing grid emissions. The campus would need 468 additional kW of PV to offset its emissions completely in 2035. This campus does not have the capability of having this quantity of PV installed, so it is recommended to install this at an alternate campus, or to consider purchasing offsets instead. The facility would require 138 tons of offsets in 2035, going down to 69 tons in 2040, assuming the gride converges to the legislated emissions rates as expected.



5.

District Wide Summary

Electric Infrastructure Assessment



Electrical Infrastructure Assessment - Introduction

As part of the Electrification Plan, Interface Engineering evaluated the available electrical system capacity at each campus to accommodate the future electrical demands from electrification, renewable energy deployment, and EV charging. The goal of this assessment is to confirm the capacity at the main campus feeders and switchgear. Downstream equipment, such as panels, wiring, and transformers, are not included in this assessment.

We have assessed the available electrical capacity at each of the District's campuses, as well as the District Offices and Brentwood Building. The available capacity has been evaluated using PG&E utility data (15-minute interval data) and PV inverter output data (hourly data provided from the district) for the period of May 2022 through August 2023.

For electrical services that include PV production, the generation data from net generation output (NGOM) meters and/or direct inverter output data is added to the consumption data reported at the main revenue meter, establishing the true demand on the service.

The demand (kW) reported for each service is a calculated value, using the consumption and PV production data (kWh). For example, if 100 kWh are consumed in a 15-min timestep, then the calculated demand for that timestep would be reported as 400 kW (100 kWh X (1/4 hours)).

Observations from Electrical Capacity Analysis

There is significant spare capacity in each of the campus’s electrical system, which will allow flexibility for electrification, PV deployment and EV charging capacity.

Electrification of natural gas systems is not expected to increase the peak demands on the existing electrical systems. This is because HVAC electrical demands are typically driven by the cooling load. I.E. more fan and compressor power is required during the summer than during the winter.

- In most cases where buildings already utilize mechanical cooling, a building electrical service upgrade will not be required solely due to electrification.

| | CCC | DVC | LMC | SRC | Brentwood | District Offices |
|-------------------------|--------|-------|-------|-------|-----------|------------------|
| Service Capacity (kW) | 12,471 | 8,646 | 8,646 | 1,663 | 1,330 | 831 |
| Max Demand + 25% (kW) | 337 | 3,417 | 2,126 | 380 | 359 | 265 |
| Available Capacity (kW) | 12,134 | 5,229 | 6,521 | 1,283 | 971 | 566 |
| % Spare Capacity | 97% | 60% | 75% | 77% | 73% | 68% |

EV Charger Planning

Given the substantial capacity remaining in each of the district’s electrical services, there is flexibility to add EV charging in strategic locations. As a hypothetical scenario, the table below indicates the number of chargers that a given campus can support. This calculation is based on using 25% of the spare capacity can be made available for EV charging. 9.6 KW chargers are used as an example, which represents high-capacity Level II chargers.

It should be noted that growth in EV charging is not accounted for in the GHG emissions calculations presented in subsequent sections of the report, as it is difficult to project how usage will increase on each campus.

| | CCC | DVC | LMC | SRC | Brentwood | District Offices |
|--|--------|-------|-------|-------|-----------|------------------|
| Service Capacity (kW) | 12,471 | 8,646 | 8,646 | 1,663 | 1,330 | 831 |
| Max Demand + 25% (kW) | 337 | 3,417 | 2,126 | 380 | 359 | 265 |
| Available Capacity (kW) | 12,134 | 5,229 | 6,521 | 1,283 | 971 | 566 |
| % Spare Capacity | 97% | 60% | 75% | 77% | 73% | 68% |
| # of 9.6 KW Chargers EV using 25% Spare Capacity | 315 | 136 | 169 | 33 | 25 | 14 |

Review of Facilities Condition Assessment (Electrical)

The following observations and commentary are made based on our review of the facilities condition assessment provided by Bureau Veritas, completed in November of 2023.

- The report indicates a large number of equipment and wiring has reached the end of its useful life. However, many of these items are still functional and there is no indication of anything faulty with the equipment. Instead of replacing this equipment, we recommend performing regular preventative maintenance, including cleaning, operating breakers, and infrared scanning to extend the useful life of the existing equipment.
- We concur with recommendations to replace equipment where there are safety concerns or replacement parts are no longer able to be sourced. For example, this would apply to panels where the original manufacturers are no longer in business, such as Zinsco and Federal Pacific gear that have known safety issues.
- We concur with recommendations to replace equipment where there are specific issues identified, such as rust, or boxes breaking off supports, etc.
- We concur with the recommendations to replace lighting greater than 15 years old to modern, energy-efficient LED lighting.

Renewable Energy Deployment



Renewable Energy Deployment Strategy

Introduction

On-site renewable energy generation is a critical component of 4CD’s sustainability plan to achieve net zero carbon emissions by 2035. The district currently has approximately 3.2 MW of photovoltaic (PV) solar panel systems across CCC, DVC, and LMC, which produce nearly 3.8 MWh annually. This represents approximately 19% of the district’s electricity consumption.

As part of its plan to increase on-site renewable production, 4CD has five additional PV projects approved by PG&E for installation but have yet to be funded. For the purposes of estimating the impact of these approved projects, it is assumed that these systems will be installed in 2026. An estimate of the total development costs are shown in the table below, which based on the information provided by Sage Renewables. These costs are based on recent quote that 4CD received for the Brentwood system, which indicated a total cost of \$7.87/watt for carport arrays. The Brentwood, DVC, and LMC installations are also planned to include battery energy storage systems (BESS), which will further enhance the cost reduction capabilities of these systems.

The tables to the right summarize the existing and planned PV systems, including their DC capacity, orientation and expected annual production rate (which vary slightly by campus and by array orientation). The table at the bottom indicates the % of electrical consumption that is met with the existing and future PV systems.

The campus site plans on the subsequent slides indicate the existing and planned PV locations on each campus, including the context of the newly planned buildings as part of the FMP. The site plans also indicate areas that may potentially be used for additional PV in the future.

The energy and carbon impact of the existing and planned arrays are discussed in more detail in the “District Energy and Carbon Timeline” chapter of this report.

The table below shows the future PV, beyond what is currently planned, that would be required in order to achieve net zero emissions for the specific campuses in 2035, and the associated cost of deployment in 2024 PV costs.

| Future PV Summary (Scenario A) | | | | | |
|--------------------------------|-----------|--------------|---------------------------------|--|--------------------------------|
| Campus | Size (kW) | Cost* | Est. Annual Production (kWh/yr) | Predicted Electrical Consumption in 2035 | % Future Load Met by Future PV |
| DVC | 3,844 | \$30,252,280 | 5,766,000 | 8,782,110 | 66% |
| CCC | 2,167** | \$17,054,290 | 3,250,500 | 5,143,509 | 63% |
| LMC | 591 | \$4,651,170 | 886,500 | 4,276,119 | 21% |
| SRC | 433 | \$3,407,710 | 649,500 | 1,413,618 | 46% |
| DO | 468*** | \$3,683,160 | 702,000 | 701,838 | 100% |
| BEC | 166 | \$1,306,420 | 249,000 | 749,521 | 33% |

*costs are based on estimates for PV projects for the district in 2024
**based on offsetting kWh instead of carbon emissions, due to the utility split for CCC between MCE and Constellation
***Due to limited space at this facility, this PV could be installed on another Constellation Campus like DVC, LMC, or SRC to have the same effect.

| Existing PV systems | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | Kwh/KW* | Annual Energy Production (kWh) |
| Contra Costa College - Lot 9 | 403 | 225 | 1053 | 424,359 |
| Diablo Valley College - Lot 1 | 567 | 270 | 1297 | 735,289 |
| Diablo Valley College - Lot 3 | 267 | 270 | 1297 | 346,247 |
| Diablo Valley College - Lot 4 | 548 | 270 | 1297 | 710,650 |
| Los Medanos College - Lot B | 763 | 150 | 1139 | 868,904 |
| Los Medanos College - Lot C | 638 | 230 | 1128 | 719,953 |
| Total | 3,186 | | | 3,805,402 |

*The existing PV production rates are 20-30% below the expected rate, based on the location and orientation of the systems. This may indicate performance issues with the panels and inverters.

| Planned PV systems | | | | | |
|-------------------------------|--------------------|------------------------------|---------|--------------------------------|--------------------------------|
| Site Name | DC Array Size (KW) | Orientation (deg from North) | kWh/K W | Annual Energy Production (kWh) | Project Development Costs (\$) |
| Diablo Valley College - Lot 5 | 878 | 270 | 1564 | 1,373,000 | \$6,909,860 |
| Contra Costa College - Lot 1 | 947 | 225 | 1551 | 1,469,000 | \$7,452,890 |
| Los Medanos College | 1,154 | 150 | 1560 | 1,800,000 | \$9,081,980 |
| San Ramon Center - Main Lot | 483 | 225 | 1580 | 763,000 | \$3,801,210 |
| Brentwood Center - Main Lot | 322 | 180 | 1556 | 501,032 | \$2,534,140 |
| Total | 3,784 | | | 5,906,032 | \$29,780,080 |

| Renewable Energy Summary | | | | |
|--------------------------|---------------------------------------|----------------------|---------------------|---------------------------|
| | Annual Electricity Consumption (kWh)* | % Met by Existing PV | % Met by Planned PV | Total Planned Renewable % |
| CCC | 4,414,407 | 10% | 33% | 43% |
| DVC | 8,618,555 | 21% | 16% | 37% |
| LMC | 4,783,853 | 33% | 38% | 71% |
| SRC | 1,200,248 | 0% | 64% | 64% |
| Brentwood | 573,479 | 0% | 87% | 87% |
| District Offices | 657,697 | 0% | 0% | 0% |
| District | 20,248,239 | 19% | 28% | 47% |

*True 2022 value that is not weather normalized

District Energy Projects




HVAC Electrification Strategy

District Wide— District Energy Project Savings and Cost Summary

| Non-FMP Energy Projects Cumulative Cost | | | | Non-FMP Energy Project Annual Cost Savings (2023 Utility Rates) | | | | |
|---|--------------|-----------------|--------------|---|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting | Controls | Electrification | Total | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| \$8,907,446 | \$12,887,625 | \$36,906,247 | \$58,701,319 | \$ 473,497 | \$ 123,178 | \$ 694,604 | -\$1,000,368 | \$290,911 |

| Non-FMP Energy Project Energy Savings (Annual Impact - Not Cumulative) | | | | Non-FMP Energy Project Annual Cost Savings (2035 Estimated Utility Rates) | | | | |
|--|--------------------------|----------------------------|----------------------------|---|------------------|-----------------------------|----------------------------------|----------------------|
| Lighting (Electric kBTU) | Controls (Electric kBTU) | Electrification (net kBTU) | Electrification (Gas kBTU) | Lighting Savings | Controls Savings | Electrification Gas Savings | Electrification Electric Penalty | Total Annual Savings |
| 7,034,350 | 1,840,186 | 22,746,482 | 35,383,416 | \$ 845,556 | \$ 219,967 | \$ 1,240,401 | -\$1,786,424 | \$519,500 |




HVAC Electrification Strategy


District Wide— District Energy GHG Reductions by Decarbonization Measure

The graph below shows the tons of CO2 averted by the type of measure. The graph shows the 15 years from the start of 2026 to the end of 2040, as well as a summation. PV provides a greater source of averted emissions early on, while electrification provides a greater amount of averted emissions by the end of the study. This is due to the improving grid emissions rate lowering the offset impact of PV, and increasing the gas replacement impact of electrification. There is also PV at the start of the study, whereas it takes time for a portfolio of electrified buildings to accumulate.

Metric Tons of CO2 Averted, by Measure District Wide




Emissions Averted from 2026 to 2040 (15 Years - Metric Tons of CO2)



District Wide Energy Timeline




District Energy and Carbon Timeline – EUI Targets



The EUIs are displayed on a per year basis, along with a campus average and 25%/40% reduction targets outlined in the 4CD sustainability report. These targets are based on 2013 benchmark campus EUIs. In order to meet these targets, significant electrification and building upgrades are necessary. The projects around the college complex of the Los Medanos College campus have a very strong impact on this campuses EUI. While both the 2030 and 2035 goals are met only one year ahead of schedule with this plan, the portfolio of electrification projects in 2034 overshoot the EUI requirements for that year. This is helpful for meeting emissions targets as well, but alternatives with some of the less convenient electrification projects removed and more PV/Offsets to replace them are shown in the District Future Energy and Carbon Scenarios portion of this report.

District Energy and Carbon Timeline – Net Emissions




This graph shows the progress towards the District’s emissions goals as outlined in the 4CD sustainability report. These targets are based on the 2013 baseline emissions. While the current plan of extensive electrification does help make this target more feasible, more on-site renewable generation or purchased offsets will be needed to achieve the 2030 and 2035 targets. The green portion of the graph shows emissions that are offset by renewable energy, so the true campus emissions are at the point where the green and blue bars intersect.

Scenarios to mitigate the remaining portion of emissions are covered in the District Future Energy and Carbon Scenarios portion of this report.

District Energy and Carbon Timeline – Emissions


District Plan Emissions by Year, Campus, and Fuel, Excluding Renewables
(metric tons CO2)



This graph shows the emissions breakdown of the entire district by fuel type, and campus. It does not include any offsetting effects of renewable proliferation in order to allow a direct comparison of the electric and gas-based emissions from consumption. The District’s sustainability plan dictates a pace of building EUI reduction and emissions reduction, and electrification is critical to meeting those goals. The reduction in gas emissions over time is driven by the electrification of the campus facilities, while the reduction in electric emissions is predominantly driven by a decrease in the emissions rate of the grid electricity occurring simultaneously with a slowly increasing electric consumption across the campuses and centers.

District Energy and Carbon Timeline – Utility Cost Trend

The current quantities of existing and planned PV for the district cancel out the expected escalation of the utility rates over time and result in a more stable total operating cost for the district. Once the planned PV is deployed, it results in more cost savings for the district than the planned portfolio of building energy projects, but the latter still has some impact. The demolition and replacement of less efficient existing buildings also has a meaningful impact on operating costs. Future PV installed to meet energy and sustainability goals will further reduce the operating costs of the district.



Planned PV is assumed to be installed in the year prior to the start of 2026.

6.

District Future Energy and Carbon Scenarios

Emissions Cost Comparison



District Energy and Carbon Timeline – Cost Per Ton of Averting Carbon

Table: Cost of Averting 1 Metric Ton of Carbon Emissions by Initial Cost (20-Year Time Horizon)

| Year | 2025 | 2035 |
|-------------------------------------|----------|-----------|
| MCE Clean Energy Purchase | \$515 | NA |
| Constellation Clean Energy Purchase | \$131 | NA |
| MCE PV | \$22,474 | \$125,078 |
| Constellation PV | \$1,411 | \$7,851 |
| Electrification | \$949 | \$1,093 |
| LED | \$813 | \$4,526 |
| ALC | \$3,287 | \$18,294 |
| Cheap Offsets Cost per Ton* | \$18 | \$55 |
| Carbon Capture Cost per Ton* | \$750 | \$650 |

*Middle of the road estimate between upper and lower bounds estimates

Table: Simple Payback in Years for Strategies Across the District

| Year | 2025 | 2035 |
|------------------|------|------|
| MCE PV | 11.6 | 12.2 |
| Constellation PV | 13.9 | 14.6 |
| Electrification | NA | NA |
| LED | 6.8 | 7.2 |
| ALC | 31.4 | 32.9 |

These tables show the district wide value of strategies that are available for dealing with carbon and operating cost goals. The values are based on the portfolio of the Non-FMP district energy projects, and hypothetical value of future PV. The initial costs are adjusted to reflect the year for the comparison, and the cost and emissions rates are averaged over a 20-year period that also constitutes the length of the comparison.

The MCE PV option is by far the most expensive in terms of dollars per ton averted. This is because of the low emissions rate associated with MCE (The positive case for deploying PV on the MCE account is that it has the best financial payback for the district, compared to the other utilities.). The two methods of carbon aversion that have the best costs in 2035, relative to their 2025 costs, are electrification projects, and carbon capture projects. The decrease in emissions from the grid over time results in a higher net savings for electrification projects over time, whilst it undercuts savings based on projects like PV, LED upgrades, and controls upgrades.

The overall cheapest option of “Cheap Offsets” are offsets that are available to purchase but use methodologies to calculate their impact which have fallen out of favor with researchers and practitioners because they have been found to not be resilient. The more expensive “Carbon Capture” projects are based on things like direct air capture and bio-char or bio-oil projects that store these CO2 products underground. This is new technology that is expected to advance in the coming years, and so our cost estimate window ranges from \$500 to \$1000 in 2025, and \$300 to \$1000 in 2035, with the middle of these windows being represented in the table. We can also see that the LED projects have the best payback of any energy project, and the ALC/controls upgrades have the least desirable cost payback (unless they are being done on a very poorly operating building), and should likely be lumped in with other work on the buildings.

District Energy and Carbon Timeline – Cost Per Ton of Averting Carbon – Cont.

These numbers are approximations based on assumptions around future emissions rates, project cost escalations, and utility cost escalations, that are likely to diverge from our forecast. The important take-away is not any specific value, but that as time goes on, a reduction in the emissions rate of the electrical grid will profoundly change the carbon impacts per dollar of the various strategies, and electrification, as well as advanced carbon capture techniques, are going to become comparatively more cost-effective ways to avert carbon as this change occurs. It is worth noting that as the grid becomes “cleaner”, the emissions that the district will have to offset from electricity use will also go down significantly. If the California grid does reach zero emissions by 2045 as legislated, complete electrification will be all that is necessary to have no emissions after that point. This also means that the best time to install PV from a carbon and utility cost perspective is as early as possible.

There are also clean energy purchase options from Both MCE and Constellation. These are cheaper up front, but the money spent on them is lost permanently, instead of contributing to a payback like PV. The Constellation option is more expensive per kWh but is cheaper per ton of carbon due to Constellation’s higher emissions rate. These estimates are provided for 2025, but not 2035, due to uncertainty around the costs of these specific services in the future.

From a financial perspective, the ROI of the projects are much more stable over the duration of the study, compared to the emissions impact.

More resources regarding carbon offsets and capture and the issues with some of the cheaper types of offsets available today are located in the appendix of this report.

Future
Scenario A:
Main Scenario



Scenario A Details

Rationale

The over-arching strategy of Scenario A is to use PV where it has a strong impact on emissions to offset emissions, electric consumption, and operating costs. For the campuses where PV is not applicable, or less impactful to the campus emissions, offsets are used to achieve the carbon goals. This is the main scenario and doesn't make any changes to the non-FMP projects outlined in the previous pages of the report.

Future PV

| Campus | PV Quantity (MW) | PV Rationale | PV Cost* |
|--------|------------------------------------|---|--------------|
| DVC | 3.844 | 100% of 2035 emissions | \$30,252,280 |
| CCC | 2.167 | 100% of 2035 electric consumption | \$17,054,290 |
| LMC | 1.059 (468 for DO + 0.591 for LMC) | 100% of 2035 emissions for LMC plus 100% of 2035 emissions for DO** | \$8,334,330 |
| DO | 0 – see LMC | 100% of 2035 emissions offset at LMC | 0 – see LMC |
| SRC | 0.433 | 100% of 2035 emissions | \$3,407,710 |
| BEC | 0.166 | 100% of 2035 emissions | \$1,306,420 |
| Total | 7.669 | | \$60,355,030 |

*All PV costs are based on 2024 project costs

**DO emissions could be associated with any of the facilities with the same emissions as DO and retain the same value and estimated cost.

Offsets

| Campus | Offset Quantity (Tons) | Offset Rationale | Offset Cost (x\$1,000) |
|--------|--|---------------------------------------|--|
| DVC | None | Emissions covered by PV | None |
| CCC | 2035: 212 2036: 197 2037: 173 2038: 154 2039: 135 2040: 115 | Remaining Emissions not covered by PV | 2035 Offset: 2-21, 2035 Capture: 42-212 2036 Offset: 2-20, 2036 Capture: 39-197 2037 Offset: 2-17, 2037 Capture: 35-173 2038 Offset: 2-15, 2038 Capture: 31-153 2039 Offset: 1-13, 2039 Capture: 27-135 2040 Offset: 1-12, 2040 Capture: 23-115 |
| LMC | None | Emissions covered by PV | None |
| DO | None | Emissions covered by LMC PV | None |
| SRC | None | Emissions covered by PV | None |
| BEC | None | Emissions covered by PV | None |
| Total | 2035-2040: 986 | | 2035-2040 Offset:10-99 2035-2040 Capture: 197-986 |

Building Projects


This plan includes all of the FMP and Non-FMP energy projects shown in the previous sections.

Offset vs PV Cost Analysis

Offsets are the most cost effective method of carbon reduction in the later years of the study (based on up front costs) with even a high end estimate of \$1000 a ton offering more tons per dollar than PV. With that being said, the money spent on CO2 offsets is lost permanently, whereas the cost of PV panels is eventually recuperated in electrical cost savings.

Scenario A – Net Emissions

4CD Greenhouse Gases Compared to Goal




In this scenario, the district is just shy of meeting its interim 2030 25% emissions goal but achieves it in the next year. It does meet its 2035 goal of net-zero emissions, using offsets to handle the last bits of gas usage and constellation electricity from CCC. Although the future PV is sized to meet the 2035 parameters for the campus, it is shown as being deployed in 2030 to approach the 25% reduction target set for that year.

| District Energy Goal | 2030 Goal | 2030 Goal Met | 2035 Goal | 2035 Goal Met |
|----------------------------|------------------------------------|---------------|-------------------|---------------|
| Emissions | 75% Reduction | Met | 100% Reduction | Met |
| Natural Gas Reduction | 30% Reduction | Met | 75% Reduction | Met |
| Electric Percent Renewable | 75% of Electricity from Renewables | Met | NA | NA |
| Campus EUI Reduction | 25% EUI Reduction | Met | 40% EUI Reduction | Met |

This scenario meets all of the campus sustainability goals.

Scenario A – Utility Cost Trend

The additional future PV added with scenario A results in near zero utility costs for the district. The cost of the offsets, which start in 2035, are included in this graph and data, but are so small that they are not visible on this graph. The more conservative future \$1000 per ton cost for carbon capture still results in offsets per year that measure in the hundreds of thousands of dollars. This low cost of offsets is enabled by the large amount of PV and electrification in this scenario.



Planned PV is assumed to be installed in the year prior to the start of 2026
and Future PV is assumed to be installed in the year prior to the start of 2030.

Future Scenario B: No Future PV, More Offsets



Scenario B Details

Rationale

The over-arching idea of Scenario B is to consider offsets in place of PV for all future emissions reductions. The advantage of this strategy is to avoid the expensive cost as well as district labor and planning burden of future PV. The downside is that money that is spent on using offsets to avert CO2 instead of PV is lost permanently, whereas PV projects have a payback. There is also broad skepticism around the merits of cheaper CO2 offset mechanisms, as well as issues with high uncertainty in future costs. Carbon capture much more reliably results in a quantity of offsets that have the advertised impact, but the cost is orders of magnitude higher. This cost is expected to go down over time as the industry grows. Due to the better financial value of PV projects, offsets only make sense in a scenario where the district is unable to finance, doesn't have space for, or is otherwise unable to pursue any future PV projects. Scenarios between A and B are a more realistic path for a partially constrained deployment of future PV relative to what is expected in scenario A.

Future PV

| Campus | PV Quantity (MW) | PV Rationale | PV Cost |
|---------------|------------------|--------------|---------|
| District-Wide | None | None | None |


Offsets

| Campus | Offset Quantity (Tons) | Offset Rationale | Offset Cost (x\$1,000) |
|---------------|------------------------|---|--|
| District-Wide | 2030-2040: 18,112 | Offset all emissions exceeding campus emissions goals | 2030-2040 Offset: 166-1,606 2030-2040 Capture: 4,501-18,112 |

Building Projects

This plan includes all of the FMP and Non-FMP energy projects shown in the previous sections/included in scenario A.

Scenario B – Net Emissions




The offsets only scenario is aligned to the 2030 and 2035 emissions target, with the offsets required per year after 2035 decreasing as the grid becomes more clean. The limit of this reduction is the remaining gas usage which drives the offsets required into the distant future, for both this scenario and scenario A. This means that PV is really an interim carbon solution, as in the long term, once the CA grid is non-emitting, the carbon emissions solution for the campus will be a trade-off between electrification and offsets. The only way to have net zero emissions and avoid offsets entirely after 2045 is to completely electrify the district.

| District Energy Goal | 2030 Goal | 2030 Goal Met | 2035 Goal | 2035 Goal Met |
|----------------------------|------------------------------------|---------------|-------------------|---------------|
| Emissions | 75% Reduction | Met | 100% Reduction | Met |
| Natural Gas Reduction | 30% Reduction | Met | 75% Reduction | Met |
| Electric Percent Renewable | 75% of Electricity from Renewables | Not Met | NA | NA |
| Campus EUI Reduction | 25% EUI Reduction | Met | 40% EUI Reduction | Met |

This scenario meets all of the campus sustainability goals, except those around the percentage of electricity that is renewable.

Scenario B – Utility Cost Trend

This graph shows the operating energy and offset costs for the campus under scenario B. This scenario has significant offset costs, which diminish over time. This presence of annual offset costs, and lack of future PV from scenario A, means that the operating costs are much higher than scenario A. However, Scenario A has about 60 million dollars worth of PV projects that are completely avoided in this scenario. However, with operating costs that are around 4-6 million dollars higher per year over the course of the 10 years of the study impacted by these projects (2030-2040), this seems like a clearly less valuable financial option in the long run. In a carbon emission constrained future, the cost of the offsets can be considered as a sort of boost to the payback of PV projects, in the window of time where PV still has a carbon impact before the grid is completely non-emitting. The fact that these cost savings will also continue for another decade after the study makes scenario A a financially obvious choice compared to this one. However, in a situation where PV deployment is limited by some other factor, or where the way that PV is credited back to the campus changes, this scenario could become much more compelling. This scenario is also conservative in its estimate of the cost of carbon offsets (\$1,000 per ton for a carbon capture technique), and real-life expected decreases in the cost of this technology could help make this scenario less financially harmful. The majority of the carbon offset purchases in this scenario occur in a window ending just beyond a decade from now, so it may be unwise to bank on significant decreases in cost. It is also important to consider that there could be constraints on carbon capture deployment beyond cost, as many organizations attempt to purchase offsets based on these technologies to meet their sustainability goals. Even if the cost were to decrease, there may still be scarcity in the actual availability of the offsets.



Future Scenario C:
Clean Electricity
Purchase, Minimal
Offsets



Scenario C Details

Rationale

Scenario C switches to 100% renewable energy electricity purchase options from MCE and Constellation, for all electricity on the 5 facilities served by those utilities. This switch occurs in 2030, to align with the campus energy goals. The remaining emissions that need to be offset from gas and the Brentwood Education Center Electricity are handled with offsets. This scenario avoids the high initial cost of PV deployment, but is less financially beneficial in the long run, since the money spent on the clean energy is lost forever, where PV has a payback. In addition, clean power agreements can be subject to some of the same issues as carbon offsets, where the savings may be double counted or used to support PV that would have already been deployed by the utility company anyway in order to meet their legislative requirements.

Future PV

| Campus | PV Quantity (MW) | PV Rationale | PV Cost |
|---------------|------------------|--------------|---------|
| District-Wide | None | None | None |

Clean Energy Purchase

| Campus | Clean Energy Purchase Quantity | Clean Energy Purchase Rationale | Clean Energy Purchase Premium* |
|---------------|--|---|--|
| District-Wide | 100% of electricity consumption for all campuses except BEC (~300,000 MWH) | Clean energy purchased for 100% of all electricity from all campuses except BEC | 2030: \$817,000 (in addition to regular electricity cost) 2040: \$1,131,000 (in addition to regular electricity cost) |

*The future costs shown for clean energy purchase are based on the current premiums escalating at the same assumed rate as electricity. In reality – the continued operation of these purchase programs and predictions of the premium cost cannot be guaranteed.


Offsets

| Campus | Offset Quantity (Tons) | Offset Rationale | Offset Cost (x\$1,000) |
|---------------|------------------------|---|---|
| District-Wide | 2030-2040: 315 | Offsets are purchased for all remaining gas use for the district, as well as electric use for BEC where clean energy purchase agreements from PG&E have not yet been explored by the district | 2030-2040 Offset: 3-31 2030-2040 Capture: 63-315 |

Building Projects

This plan includes all of the FMP and Non-FMP energy projects shown in the previous sections/included in scenario A.

Scenario C – Net Emissions




This scenario has the campus meeting its 2030 75% emissions reduction target, as well as its 2035 100% emissions reduction target. Only a small amount of offsets are needed, which deal with the small amount of remaining gas consumed each year after the electrifications are completed.

| District Energy Goal | 2030 Goal | 2030 Goal Met | 2035 Goal | 2035 Goal Met |
|----------------------------|------------------------------------|---------------|-------------------|---------------|
| Emissions | 75% Reduction | Met | 100% Reduction | Met |
| Natural Gas Reduction | 30% Reduction | Met | 75% Reduction | Met |
| Electric Percent Renewable | 75% of Electricity from Renewables | Met | NA | NA |
| Campus EUI Reduction | 25% EUI Reduction | Met | 40% EUI Reduction | Met |

This scenario meets all of the campus sustainability goals.

Scenario C – Utility Cost Trend

This scenario incurs about a million dollars a year in operating cost from the clean energy premiums, and also loses out on about 6 million dollars of 2030 operational cost savings compared to the “Future” PV that is planned for scenario A. This plan does avert the 60 million dollars of PV installation costs in scenario A (based on 2024 PV costs), but with the higher utility operating costs, and clean energy premium cost, the payback for that investment in scenario A compared to this scenario is around 10 years. Clean energy purchase could be a good small piece of a larger strategy that still relies primarily on PV, especially for a facility like the district offices, which doesn’t have space for its own PV. There is also a lot of uncertainty around the availability and cost of these clean energy purchase programs in the future, and relying on them heavily as a strategy, only for them to be taken away as an option by a utility, could leave the district scrambling to find other ways to meet its goals.



Planned PV is assumed to be installed in the year prior to the start of 2026.

Future Scenario D: Delayed Electrification, PV Matched to kWh Consumption, Offsets for Gas



Scenario D Details

Rationale

This scenario removes some of the non-FMP electrifications and matches the PV to kWh consumption and offsets to the consumption of gas. The main benefit of this scenario is that in the other scenarios, all of the large gas using facilities across the district were electrified by 2035. For most of the projects, this was fine and could coincide with the end of remaining useful life on the major HVAC equipment being electrified. Some projects, however, have newer gas using equipment and electrifications were assigned well before the end of the useful life, as well as before planned “Phase 2” renovations in the full master plan. Delaying these electrifications will avert the waste of replacing equipment that still has significant RUL.

Future PV

| Campus | PV Quantity (MW) | PV Rationale | PV Cost* |
|--------|------------------------------------|---|--------------|
| DVC | 3.584 | 100% of 2035 electricity consumption | \$28,206,080 |
| CCC | 1.988 | 100% of 2035 electricity consumption | \$15,645,560 |
| LMC | 0.953 (468 for DO + 0.485 for LMC) | 100% of 2035 electricity consumption for LMC plus 100% of 2035 electricity for DO** | \$7,500,110 |
| DO | 0 – see LMC | 100% of 2035 electricity offset at LMC | See LMC |
| SRC | 0.434 | 100% of 2035 electricity consumption | \$3,415,580 |
| BEC | 0.051 | 100% of 2035 electricity consumption | \$401,370 |
| Total | 7.01 | 100% of 2035 electricity consumption | \$55,168,700 |

*All PV costs are based on 2024 project costs
**DO emissions could be associated with any of the facilities with the same emissions as DO and retain the same value and estimated cost.

Offsets

| Campus | Offset Quantity (Tons) | Offset Rationale | Offset Cost (x\$1,000) |
|---------------|------------------------|--------------------------------|---|
| District-Wide | 2030-2040: 4333 | All gas use, up to carbon goal | 2030-2040 Offset: 42-413 2030-2040 Capture: 952-4333 |

Building Projects


This plan includes all of the FMP and Non-FMP energy projects shown in the previous sections, except the following projects electrifications:

| Building | Electrification Cost Averted |
|--|------------------------------|
| BEC | \$2,561,142 |
| LMC Math | \$1,071,968 |
| LMC Kinesiology/Athletics | \$1,078,740 |
| CCC Performing Arts Center | \$718,935 |
| CCC Atheltic Training and Kinesiology Center | \$175,913 |
| CCC Gymnasium | \$875,525 |
| CCC Student Services | \$660,050 |
| DVC Student Services | See HSF Below |
| DVC Hospitality/Food Court | \$4,001,164 |

Collectively, avoiding these electrifications saves 11 million out of the 37 million dollars prescribed for electrification in scenarios A, B, and C.

Scenario D – EUI Targets


Projected Campus (Total Energy) EUI (kBtu/yr) by Year



The removed electrifications increase the district wide EUI about halfway from its 2035 value in scenarios A, B, and C, to its value defined by the sustainability goals. There is room to cut electrification further, if necessary, but this would require more offsets to be purchased in the later years of the study. It is still recommended to electrify these buildings when the equipment is at the end of its life, just not during the study window in this scenario.

Scenario D – Net Emissions

4CD Greenhouse Gases Compared to Goal




This scenario is somewhere in between scenarios A and B in terms of its use of PV vs Offsets. It affixes the quantity of PV to the 2035 electricity consumption, which means that going forward, as the grid becomes less emitting, both the electricity emissions and PV emissions offset are impacted equally, meaning there is no change caused to the campus emissions from the grid level change. The PV is installed in 2030, in order to help meet the 2030 campus targets. Offsets are then paired with gas consumption to handle the remaining gas from the non-electrified facilities.

| District Energy Goal | 2030 Goal | 2030 Goal Met | 2035 Goal | 2035 Goal Met |
|----------------------------|------------------------------------|---------------|-------------------|---------------|
| Emissions | 75% Reduction | Met | 100% Reduction | Met |
| Natural Gas Reduction | 30% Reduction | Met | 75% Reduction | Met |
| Electric Percent Renewable | 75% of Electricity from Renewables | Met | NA | NA |
| Campus EUI Reduction | 25% EUI Reduction | Met | 40% EUI Reduction | Met |

This scenario meets all of the campus sustainability goals.

Scenario D – Utility Cost Trend

This scenario averts about 5 million dollars of PV spending (2024 PV costs) relative to scenario A, and about 11 million dollars of electrification spending (based on the scheduled years of the projects in scenario A and B) relative to scenarios A and B. It has operating costs that are millions of dollars below scenario B and about \$800,000 more per year than scenario A, assuming \$1000 per ton of offsets purchased, which is a conservative assumption given that this scenario has the offsets being purchased later on in the study on average than in scenario B. The main financial benefit of this scenario is delaying the investment in electrification for many buildings where the equipment still has significant remaining useful life. This gives the opportunity to delay this investment until the end of the useful life, at which point the electrification cost is less impactful, since new equipment is required anyway.



Planned PV is assumed to be installed in the year prior to the start of 2026
and Future PV is assumed to be installed in the year prior to the start of 2030.

Scenario Future Implementation

The previously described scenarios are all different viable ways of reaching the district goals, and it is likely that the path that the district ends up taking to meet them will end up somewhere between the scenarios, instead of matching any one of them perfectly. The important thing is to consider the factors by which deviations from our predictions could impact what strategies are most valuable:

1. If the grid were to fail to improve its emissions rates at speed legislated by CA SB100, then this would increase the relative strength of PV projects and LED projects, whilst decreasing the positive impacts of electrification. Likewise, if the grid were to lower its emissions significantly faster than expected, electrification should become a higher priority.

2. Changes to the cost and efficacy of various carbon offset and removal programs should be monitored in order to make a judgement call of how much the district can rely on those offerings. Many organizations and institutions are moving away from offsets as academic research often finds the actual carbon impacts to be overstated. There is also a belief among some that the costs of offsets will change drastically in the coming years. Carbon removal technology is currently at a price around \$1,000 per ton and is not widely available to purchase, but is expected to decrease in cost and expand in scale with government support and economies of scale. It is important to monitor changes to this technology in the future. Luckily, there is still a few years before the district would need to decide how much to rely on this tool. More resources on Carbon Offset and Removal are located in appendix A.



Scenario Future Implementation – Cont.

The effectiveness of electrification increases with improvements to the emissions rate of the grid, so it is important to consider that both the trans-critical heat pump technology, and the grid, will improve significantly over the period of time covered in this study. The current scenarios save a large amount of electrification projects until near the 2035 net zero district goal. Moving around the campus projects within the window of 2024-2034 will not impact the campus' ability to meet its goals, but it may be a good idea to make sure some earlier electrification and trans-critical heat pump projects are done, so that there is familiarity with the nature of the projects when the larger bulk of planned electrifications approach in the 2030s.

The building benchmarking study was primarily based on 2022 weather normalized data, due to the impacts of covid and construction/demolition to the campus operation in prior years. This means that we should expect the energy trends of the campus to vary going forward, based on both the small chronological sample of our data, as well as year by year weather differences. The quantities of PV and carbon offsets needed could go up or down in the long run due to changes in operation relative to 2022. Individual years with weather that causes higher or lower energy use than expected may cause the district to not have its energy and emissions completely covered by PV, or the district could end up with more PV than needed.



APPENDIX A

Resources and Information Around Carbon Offsets and Capture

Carbon Offset Resources and Information

[The University of California has all but dropped carbon offsets—and thinks you should, too | MIT Technology Review](https://www.technologyreview.com/2023/11/30/1084104/the-university-of-california-has-all-but-dropped-carbon-offsets-and-thinks-you-should-too/)

<https://www.technologyreview.com/2023/11/30/1084104/the-university-of-california-has-all-but-dropped-carbon-offsets-and-thinks-you-should-too/>

[2023 Climate Tech Companies to Watch: Climeworks and its carbon-sucking fans | MIT Technology Review](https://www.technologyreview.com/2023/10/04/1080109/2023-climate-tech-companies-climeworks-carbon-removal-direct-air-capture/)

<https://www.technologyreview.com/2023/10/04/1080109/2023-climate-tech-companies-climeworks-carbon-removal-direct-air-capture/>

[What is the most cost-effective way to buy carbon offsets? | MIT Climate Portal](https://climate.mit.edu/ask-mit/what-most-cost-effective-way-buy-carbon-offsets)

<https://climate.mit.edu/ask-mit/what-most-cost-effective-way-buy-carbon-offsets>

[Carbon offsets price may rise 3,000% by 2029 under tighter rules | Insights | Bloomberg Professional Services](https://www.bloomberg.com/professional/insights/trading/carbon-offsets-price-may-rise-3000-by-2029-under-tighter-rules/)

<https://www.bloomberg.com/professional/insights/trading/carbon-offsets-price-may-rise-3000-by-2029-under-tighter-rules/>

[Price slump in 2023 clouds outlook for voluntary carbon market | S&P Global Commodity Insights \(spglobal.com\)](https://www.spglobal.com/commodityinsights/en/market-insights/latest-news/energy-transition/010524-price-slump-in-2023-clouds-outlook-for-voluntary-carbon-market)

<https://www.spglobal.com/commodityinsights/en/market-insights/latest-news/energy-transition/010524-price-slump-in-2023-clouds-outlook-for-voluntary-carbon-market>